



PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 56944

1. OWNER Andrew Spinal ADDRESS AT WELL LOCATION 1050
MAILING ADDRESS 1050 W. 9th St,
Silver Springs, NV 89429
2. LOCATION 3/4 SE 1/4 Sec. 13 T. 17 N/S R. 24 E. Lyon Co. County
PERMIT NO. 017-264-11 N39.332501
Issued by Water Resources Parcel No. W 119.23129 N427 Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
5. WELL TYPE
 Cable Rotary RVC
 Air Other mud

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thick-ness |
|--------------------------------|---------------|------------|------------|------------|
| <u>White Cobbles with silt</u> | | <u>0</u> | <u>24'</u> | <u>24</u> |
| <u>Gray Clay</u> | | <u>24</u> | <u>47</u> | <u>23</u> |
| <u>Broken Basalt and clay</u> | | <u>47</u> | <u>148</u> | <u>101</u> |
| <u>Volcanic Rock</u> | | <u>148</u> | <u>192</u> | <u>44</u> |
| <u>Fractured Basalt</u> | | <u>192</u> | <u>220</u> | <u>8</u> |
| <u>eps,</u> | | | | |
| <u>39° 19.962 N,</u> | | | | |
| <u>119° 13.927 W,</u> | <u>WGS 84</u> | | | |

8. WELL CONSTRUCTION
Depth Drilled 220' Feet Depth Cased 220' Feet
HOLE DIAMETER (BIT SIZE)
From 10 5/8 inches To 0 inches
Feet 220' Feet
Inches _____ Feet _____ Feet
Inches _____ Feet _____ Feet

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|-------------|
| <u>10 5/8</u> | <u>131bs</u> | <u>.188</u> | <u>71</u> | <u>20'</u> |
| <u>10 5/8</u> | <u>pvc</u> | <u>SR 21</u> | <u>20</u> | <u>220'</u> |

Perforations:
Type perforation Samed
Size perforation 1/2 x 4" 4 Rows
From 180' feet to 220' feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
Depth of Seal 50' Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout
Gravel Packed: Yes No
From 50 feet to 220' feet

9. WATER LEVEL
Static water level 71 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature Cold °F Quality Clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Trach Drilling Inc. Contractor
Address PO Box 599 Contractor
Silver Springs, NV 89429
Nevada contractor's license number issued by the State Contractor's Board 31841
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1740
Signed Patrick A. Spach
By driller performing actual drilling on site or contractor
Date March 31/07

Date started February 27/07, 20
Date completed March 2/07, 20

7. WELL TEST DATA

| TEST METHOD: | G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|--|--------------|-------------------------------|---------------|
| <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift | <u>15-18</u> | <u>6000 50</u> | <u>12 hrs</u> |