WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
# DIVISION OF WATER RESOURCES
# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 102960
Permit No
Basin 162

NOTICE OF INTENT NO. 31189

1. OWNER C.R. HOMES
MAILING ADDRESS 2180 E TRACI
PAHRUMP, NV

ADDRESS AT WELL LOCATION 2180 E TRACI

2. LOCATION SW 1/4 SW 1/4 Sec. 1 T 22S N/S R 53E E NYE County
PERMIT NO. Issued by Water Resources
41-381-25 Parcel No.
CALVADA VALLEY UNIT 4 Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| SANDY CLAY | | 0 | 14 | 14 |
| CLAY | | 14 | 38 | 24 |
| LIMESTONE | | 38 | 42 | 4 |
| CLAY | | 42 | 72 | 30 |
| LIMESTONE | WB | 72 | 76 | 4 |
| CLAY | | 76 | 104 | 28 |
| CALICHE | WB | 104 | 114 | 10 |
| CLAY | | 114 | 128 | 14 |
| CALICHE | WB | 128 | 132 | 4 |
| CLAY | | 132 | 148 | 16 |
| CALICHE | WB | 148 | 151 | 3 |
| CLAY | | 151 | 240 | 89 |

WGS 84
N 36 DEGREES 03.989
W 115 DEGREES 58.314

Date started 6/4/2007 , 19__
Date completed 6/6/2007 , 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

8. WELL CONSTRUCTION
Depth Drilled 240 Feet Depth Cased 240 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | To |
|---|---|---|---|
| 12 | Inches | 0 Feet | 240 Feet |
| | Inches | Feet | Feet |
| | Inches | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 8 | 3.63 | .250 | 0 | 240 |

Perforations:
Type perforation SAWCUT
Size perforation 1/8 X 3
From 60 feet to 80 feet
From 100 feet to 240 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 240 feet

9. WATER LEVEL
Static water level 72 feet below land surface
Artesian flow G.P.M. P.S.I
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name GREAT BASIN DRILLING CO. OF NEVADA, INC. Contractor
Address 1220 E MANSE RD Contractor
PAHRUMP, NV. 89048
Nevada contractor's license number issued by the State Contractor's Board 47333
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
Signed (By driller performing actual drilling on-site or contractor)
Date 6/6/2007

USE ADDITIONAL SHEETS IF NECESSARY