

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. S8119

1. OWNER John Gulkegos ADDRESS AT WELL LOCATION 9225 HOPE TRAIL
 MAILING ADDRESS _____
 2. LOCATION SE 34 SW 17 T. 17 N/S R. 23 E. LYON County
 PERMIT NO. _____ Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SAND-ROCK		0	9	9
BROWN CLAY-ROCK		9	41	32
BROWN STICKY CLAY		41	80	39
FRACTURED ROCK		80	116	36
BROWN CLAY-LAVA ROCK		116	208	92
BROWN STICKY CLAY		208	241	33
LAVA ROCK		241	300	59

S131700°N
T11931400°W
N39.377103
W 119.383239 NAD83

8. WELL CONSTRUCTION
 Depth Drilled 300 Feet Depth Cased 300 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 7/8 Inches To 8 0 Feet
 From 9 7/8 Inches To 300 Feet
 Casing Schedule

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>14</u>	<u>.188</u>	<u>1</u>	<u>20</u>
<u>6 5/8</u>	<u>4</u>	<u>SDR21</u>	<u>20</u>	<u>300</u>

Perforations:
 Type perforation GRINDER CUT
 Size perforation .045" x 4"
 From _____ feet to _____ feet
 From 240 feet to 300 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 56 FT Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 56 feet to 300 feet

9. WATER LEVEL
 Static water level 206 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature COLD F Quality CLEAR

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name BLAIN DRILLING CO. INC.
 Address P.O. Box 1255 Carson City, NV 89702
 Nevada contractor's license number issued by the State Contractor's Board 46498
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2167
 Signed Jack Dotson
 Date 27 DEC 06

Date started 30 NOV, 2006
 Date completed 4 DEC, 2006

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>15-17</u>	<u>20 ft</u>	<u>3.5</u>