



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 56943

1. OWNER Andrew Spence ADDRESS AT WELL LOCATION 1020 W. 8th St, Silver Springs NV 89429
 MAILING ADDRESS _____
 2. LOCATION NE 1/4 SE 1/4 Sec. 13 T. 17N N/S R. 24 E Lyon Co County
 PERMIT NO. 017-254-10 Parcel No. N39.336368 W 119.230529 N4927 Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other mixed

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Soil & Silt		0	16	16
Gray clay		16	39	23
Broken Rock and sand		39	80	41
Volcanic Rock Broken with Clay		80	162	82
Fractured Basalt	✓	162	193	31
Red Conifer Basalt	✓	193	200	7'
GPS				
39° 20.176 N				
119° 13.891 W				

8. WELL CONSTRUCTION
 Depth Drilled 200 Feet Depth Cased 201 Feet
 HOLE DIAMETER (BIT SIZE)
 From 0 To 200 Feet
 Inches _____ Feet _____ Feet
 Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6.25</u>	<u>131bs</u>	<u>.188</u>	<u>41</u>	<u>20</u>
<u>6.25</u>	<u>PVC</u>	<u>SDR 21</u>	<u>20</u>	<u>200</u>

Perforations:
 Type perforation Sawed
 Size perforation 18 x 4" 4# Pore
 From _____ feet to _____ feet
 From 160 feet to 200 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50'
 Neat Cement
 Cement Grout
 Concrete Grout
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 50 feet to 200 feet

9. WATER LEVEL
 Static water level 60 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature Cold °F Quality clean

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Teach Drilling Inc. Contractor
 Address PO Box 5990 Contractor
Silver Springs NV 89429
 Nevada contractor's license number 31841
 issued by the State Contractor's Board
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1740
 Signed Patrick Teach
 By driller performing actual drilling on-site or contractor
 Date March 3/07

Date started March 19/07, 20
 Date completed March 20/07, 20

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>50</u>	<u>6pm</u>	<u>20 min</u>