STATE OF NEVADA

DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

PRINT OR TYPE ONLY

Log No. 102978
Permit No.
Basin 099

NOTICE OF INTENT NO. 57240

1. OWNER **Ron Anderson**
MAILING ADDRESS **P.O. Box 21182 Reno, NV 89515**
SE NE

ADDRESS AT WELL LOCATION
16300 Red Rock Rd Reno, NV 89506
Subdivision Name: *County:* **Washoe**

2. LOCATION **NW¼NW¼ Sec9T23N/ R18E**
Latitude **39.87620 N** UTM E ☐ NAD 27
Longitude **119.95983 W** N ☒ NAD 83/WGS 84

PERMIT/WAIVER NO. **N/A** (*Issued by Water Resources*) **078-212-04** (Parcel. No.)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other **mud**

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
DG		0	25	25
DG/Boulders		25	90	65
DG	X	90	170	80
Brown Clay		170	185	15
Green Clay		185	200	15
Granite	X	200	500	300

N 39.876316
W 119.959815 NAD22

Date started: 7-24, 20 06
Date completed: 8-19, 20 06

9. WELL CONSTRUCTION
Depth Drilled **500** Feet Depth Cased **500** Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
12 1/4	Inches	0	Feet	400	Feet
10	Inches	400	Feet	500	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8 steel	17	.188	0	400
6 5/8 PVC	4.07	.316	-1	500

Perforations
Type of perforation **Factory**
Size of perforation **.032**

From	150	feet to	170	feet
From	175	feet to	200	feet
From	460	feet to	500	feet
From	420	feet to	440	feet
From		feet to		feet

Annular Seal: ☒ Yes ☐ No

☒ Neat Cement	0	to 100	☒ Pumped	☐ Poured
☐ Cement Grout		to	☐ Pumped	☐ Poured
☐ Concrete Grout		to	☐ Pumped	☐ Poured
☐ ≥30% Bentonite Grout		to	☐ Pumped	☐ Poured

Gravel Pack: ☒ Yes ☐ No 100 to 500 ☐ Pumped ☐ Poured
Type: **3/8 pea**
Bentonite Chips: ☐ Yes ☒ No to ☐ Pumped ☐ Poured
Type:

7. *Water Level*
Static water level: **Artesian** feet below land surface
Artesian Flow: **15** G.P.M. **none** P.S.I
Water Temperature: **cool** °F
Quality: **good**

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Approx.	50	300	4 hrs.

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name **Miller & Son's Drilling** (CONTRACTOR)
Address **P.O. Box 8056** (CONTRACTOR)
Reno, NV. 89507
Nevada contractor's license number issued by the *State Contractor's Board* **37915**
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* **1418**
Signed Bruce Miller
By driller performing actual drilling on site or contractor
Date 9-16-06

RECEIVED 2007 JAN 17 AM 11:19

(Rev 05-06) USE ADDITIONAL SHEETS IF NECESSARY

Forms Provided by Forms-On-A-Disk · (214) 340-9429 · FormsOnADisk.com