STATE OF NEVADA

DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

PRINT OR TYPE ONLY

OFFICE USE ONLY
Log No. 102984
Permit No.
Basin 092A

NOTICE OF INTENT NO. 56445

1. OWNER Dyanne Read
MAILING ADDRESS 650 Encanto Dr. Reno, NV. 89506

ADDRESS AT WELL LOCATION 10980 Red Rock Rd.
Reno, NV. 89506
Subdivision Name: County: Washoe

2. LOCATION NW¼NW¼ Sec25T21N/ R18E
PERMIT/WAIVER NO. 086-181-13
Issued by Water Resources Parcel. No.

Latitude 39.66483 UTM E ☐ NAD 27
Longitude 119.92217 N ☒ NAD 83/WGS 84

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandy Clay		0	175	175
Course Sand		175	220	45
DG		220	255	35
Course Sand/little clay	X	255	350	95
Clay/Sand		350	450	100

N 39.664942
W 119.921159 NAD27

Date started: 12-30, 20 05
Date completed: 1-5, 20 06

7. Water Level
Static water level: 120 feet below land surface
Artesian Flow: none G.P.M. none P.S.I
Water Temperature: cool °F
Quality: good

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Approx	25	200	2

STATE ENGINEER'S OFFICE
2007 JAN 17 AM 11:19
RECEIVED

9. WELL CONSTRUCTION
Depth Drilled 450 Feet Depth Cased 450 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12 1/4 Inches	0 Feet	50 Feet
10 Inches	50 Feet	450 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8 steel	14	.188	-1	19
6 5/8 PVC	4.07	.316	19	450

Perforations:
Type of perforation mill slot
Size of perforation .032
From 170 feet to 210 feet
From 290 feet to 350 feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☒ Neat Cement 0 to 52 ☒ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured
Gravel Pack: ☒ Yes ☐ No 52 to 450 ☐ Pumped ☐ Poured
Type: 3/8 Pea
Bentonite Chips: ☐ Yes ☒ No to ☐ Pumped ☐ Poured
Type:

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Miller & Son's Drilling (CONTRACTOR)
Address P.O. Box 8056 (CONTRACTOR)
Reno, NV. 89507
Nevada contractor's license number issued by the State Contractor's Board 37915
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1418
Signed Bruce Miller
By driller performing actual drilling on site or contractor
Date 1-29-06

(Rev 06-06) USE ADDITIONAL SHEETS IF NECESSARY

Forms Provided by Forms-On-A-Disk • (214) 340-9429 • FormsOnADisk.com