STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 102985
Permit No.
Basin 0070

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 51371

1. OWNER Randy McCoy
MAILING ADDRESS 7900 Airport Road
Winnemucca NV 89445

ADDRESS AT WELL LOCATION 4990 Cessna Dr.
Winnemucca NV 89445
Subdivision Name: Airport Residential Estates County: Humboldt

2. LOCATION NW ¼ NW ¼ Sec 23 T 35N N/S R 37 E
PERMIT/WAIVER No. 014-083-01
Issued by Water Resources Parcel No.

Latitude 40° 53.906
Longitude 117° 47.530
UTM E 11 433273 [x] NAD 27
N 4527562 [ ] NAD 83/WGS 84

3. WORKED PERFORMED
[x] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Other

4. PROPOSED USE
[x] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[x] Air [ ] Other Symetrix

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	60	60
Clay & Sand		60	80	20
Sand & Gravel	X	80	130	50
Clay		130	135	5
gravel	X	135	160	25

N 40.898433
W 117.792167 NAD27

N 40.898337
W 117.793131 NAD83

Date started: 10-Jan, 20 07
Date completed: 15-Jan, 20 07

7. Water Level
Static water level: 58 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: Cool °F
Quality: Good

8. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
35		1

9. WELL CONSTRUCTION
Depth Drilled 160 Feet Depth Cased 160 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
12.5	Inches	0	Feet	20	Feet
10.625	Inches	20	Feet	58	Feet
7.250	Inches	58	Feet	160	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6.625		.188	+1.5	160

Perforations:
Type of perforation punched
Size of perforation 1.250 x .188
From 138 feet to 158 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: [x] Yes [ ] No

[ ] Neat Cement	to		[ ] Pumped	[ ] Poured
[ ] Cement Grout	to		[ ] Pumped	[ ] Poured
[x] Concrete Grout	4 to 20		[ ] Pumped	[x] Poured
[x] ≥30% Bentonite Grout	20 to 58		[ ] Pumped	[x] Poured

Gravel Pack: [ ] Yes [x] No to [ ] Pumped [ ] Poured
Type:
Bentonite Chips: [ ] Yes [ ] No to [ ] Pumped [ ] Poured
Type:

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name American Drilling & Pump Service
Contractor
Address 3040 Callahan St
Contractor
Winnemucca, NV 89445
Nevada contractor's license number issued by the *State Contractor's Board* 0020578
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 2208
Signed
By driller performing actual drilling on site or contractor
Date 1/26/2007

(Rev. 06-06)

USE ADDITIONAL SHEETS IF NECESSARY