

12 WELLS

WHITE-DIVISION OF WATER RESOURCES  
CANARY-CLIENT'S COPY  
PINK-WELL DRILLER'S COPY

STATE OF NEVADA  
DIVISION OF WATER RESOURCES

OFFICE USE ONLY  
Log No. 103008  
Permit No.  
Basin 212

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT  
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 26706

1. OWNER WESTERN SUMMIT  
MAILING ADDRESS 5857 E. FLAMINGO RD LAS VEGAS, NV  
ADDRESS AT WELL LOCATION 5857 E. FLAMINGO RD. LAS VEGAS  
2. LOCATION NW 1/4 Sec. 22 T. 21 N. R. 62 E. CLARK County  
PERMIT NO. DW-1313 Issued by Water Resources Parcel No. 161-22-101-001 Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other  
4. Dewatering PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other BUCKET

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
CLAY	✓	0	15	15
F-SILTY SAND	✓	15	30	15
CLAY	✓	30	55	25

DONOR  
RECEIVED  
JUL 02 2007  
LAS VEGAS OFFICE

8. WELL CONSTRUCTION  
Depth Drilled 55 Feet Depth Cased 55 Feet  
HOLE DIAMETER (BIT SIZE)  
From 0 To 55  
Inches 24 Feet 55  
Inches Feet  
Inches Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
14	24.2			
14	36.7	.250	0	16

Perforations:  
Type perforation LOUVERED  
Size perforation .100  
From 39 feet to 55 feet  
From feet to feet  
From feet to feet  
From feet to feet  
From feet to feet

Surface Seal:  Yes  No Seal Type:  
Depth of Seal \_\_\_\_\_  Neat Cement  
Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
Gravel Packed:  Yes  No  
From 0 feet to 55 feet

9. WATER LEVEL  
Static water level 16 feet below land surface  
Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

Date started 6-7-07, 19\_\_\_\_\_  
Date completed 6-7-07, 19\_\_\_\_\_

7. WELL TEST DATA

TEST METHOD:	Bailer	Pump	Air Lift	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	150	40	1/2 HR

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name KELLEY DEWATERING Contractor  
Address 5175 CLAY AVE Contractor  
WYOMING, WY. 82001  
Nevada contractor's license number 50826 issued by the State Contractor's Board.  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller ABDS 2149  
Signed [Signature]  
By driller performing actual drilling on site or contractor  
Date JUNE 29, 2007