WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 103062
Permit No. 71236
Basin 212

NOTICE OF INTENT NO. 31005

1. OWNER Ruffin Gaming LLC, New Frontier
MAILING ADDRESS Hotel and Casino 3120 S. Las Vegas Blvd, Las Vegas 89109
ADDRESS AT WELL LOCATION 3120 S Las Vegas Blvd, Las Vegas NV

2. LOCATION NW ¼ NW ¼ Sec. 16 T 21 N/S R 61 E Clark County
PERMIT NO. 71236 (Issued by Water Resources) | 162-16-101-011 (Parcel No.) | Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other Unk

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Abandoned 12" well to 850' Depth.				
Pulled system completely from the well.				
Perforated casing with mill knife perforator from 850' to 60' - then encountered cement seal.				
Pumped in 54 yards of neat cement through a tremmie hose from the bottom of the well to surface completely filling the well.				
plugging of log 35702				
WGS 84 N 36 07 47 W 115 10 21				

RECEIVED JUL 12 2007 LAS VEGAS OFFICE

Date started 7/5/07
Date completed 7/11/07

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 850' Feet Depth Cased Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
12				

Perforations:
Type perforation
Size perforation
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☐ No
Depth of Seal
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☐ No
From feet to feet

9. WATER LEVEL
Static water level 96' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name T.D.C. Drilling (Contractor)
Address 2870 W Pebble Rd (Contractor)
Las Vegas, NV 89123
Nevada contractor's license number issued by the State Contractor's Board 59948
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2316
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 7-11-07

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627