

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **31195**

1. OWNER **SPALDING HOMES** ADDRESS AT WELL LOCATION **3680 S RAVINE**
 MAILING ADDRESS **3680 S RAVINE**
PAHRUMP, NV

2. LOCATION **NW** 1/4 **SW** 1/4 Sec. **35** T **20S** N/S R **53E** E **NYE** County
 PERMIT NO. **41-101-06** Parcel No. **CALVADA VALLEY UNIT 3** Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Municipal/Industrial Irrigation Monitor Test Stock
 5. WELL TYPE
 Cable Rotary RVC Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
CLAY & CALICHE		0	80	80
CALICHE	WB	80	82	2
CLAY		82	124	42
CALICHE	WB	124	128	4
CLAY		128	168	40
CALICHE	WB	168	179	11
CLAY		179	214	35
CALICHE	WB	214	218	4
CLAY		218	240	22
WGS84				
N 36 DEGREES 09.992				
W 115 DEGREES 59.524				

8. WELL CONSTRUCTION
 Depth Drilled **220** Feet Depth Cased **220** Feet
 HOLE DIAMETER (BIT SIZE)
 From **0** Feet To **240** Feet
10 Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	3.63	.250	0	240

Perforations:
 Type perforation **SAWCUT**
 Size perforation **1/8 X 3**
 From **120** feet to **140** feet
 From **160** feet to **180** feet
 From **200** feet to **220** feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal **50** _____ Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From **50** feet to **240** feet

9. WATER LEVEL
 Static water level **65** feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name **GREAT BASIN DRILLING CO. OF NEVADA, INC.** Contractor
 Address **1220 E MANSE RD** Contractor
PAHRUMP, NV. 89048
 Nevada contractor's license number issued by the State Contractor's Board **47333**
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller **1642**
 Signed *[Signature]*
 By driller performing actual drilling on-site or Contractor
 Date **6/14/2007**

Date started **6/13/2007**, 19
 Date completed **6/13/2007**, 19

7. WELL TEST DATA

TEST METHOD:	TEST METHOD:		Time (Hours)
	G.P.M.	Draw Down (Feet Below Static)	
<input type="checkbox"/> Bailer	<input type="checkbox"/> Pump	<input type="checkbox"/> Air Lift	