

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

Permit No. _____
 Basin (07)

NOTICE OF INTENT NO. 59083

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

1. OWNER Oscar Reese
 MAILING ADDRESS 1354 El Dorado # E
Gardnerville, NV 89410

ADDRESS AT WELL LOCATION 2830 Hwy 208 Wellington
NV.

2. LOCATION NW 1/4 SE 1/4 Sec. 2 T 10N N/S R 23E E Lyon County

PERMIT NO. _____ Parcel No. 010-642-05 Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sand silt		0	20	20
Cobbles Gravel sand		20	40	20
Sand gravel	x	40	140	100
NAD 83 N 38.75725 W 119.37809				
<u>N 38.757343</u>				
<u>W 119.377107 NAD83</u>				

8. WELL CONSTRUCTION

Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

	From	To	
<u>10 5/8</u> Inches	<u>0</u> Feet	<u>140</u> Feet	
Inches	Feet	Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>12.92</u>	<u>.188</u>	<u>+2</u>	<u>140</u>

Perforations:

Type perforation Machine cut
 Size perforation 3/32 x 3

From	To	From	To
<u>120</u> feet to	<u>140</u> feet		
feet to	feet		
feet to	feet		
feet to	feet		
feet to	feet		

Surface Seal: Yes No
 Depth of Seal 100
 Placement Method: Pumped Poured
 Seal Type: Neat Cement Cement Grout Concrete Grout

Gravel Packed: Yes No
 From 100 feet to 140 feet

9. WATER LEVEL

Static water level 34 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature Cool °F Quality Not tested

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Bruce Mackay Pump & Well Service, Inc. Contractor
 Address 1600 Mt. Rose Hwy Contractor
Reno, NV 89511
 Nevada contractor's license number issued by the State Contractor's Board 23096
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1790
 Signed R. Bruce Mackay
 By driller performing actual drilling on-site or contractor
 Date 2/5/2007

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>40</u>	<u>3</u>	<u>06:11:00</u>