39° 32.330N / 118° 59.791W

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 103082
Permit No.
Basin 101

NOTICE OF INTENT NO. 56933

1. OWNER Highway Road Boulders
MAILING ADDRESS Reno NV
ADDRESS AT WELL LOCATION Hwy 50 alt Fallon Fernley 1/4 m W Bench Rd.

2. LOCATION ~~SW~~ NE 1/4 SW 1/4 Sec. 06 T. 19N N/S R 27 E Churchill County

PERMIT NO. C-244 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☒ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand Gravels		1	23	
Clay, Sands		23	30	
Gravels, Sands		30	43	
Gravels		43	57	
Clay (~~Some Clays~~)		57	126	
Some Sand, Gravel				
Layers.		126		
Sands, Gravels		126	152	
Some Clay layers				
Gravels, Some		152	196	
Cobbles				
Clay		196	205	
Gravels		205	232	
Clay		232	301	
Gravels, Cobbles		301	400	
N 39.538936				
W 118.495533 NAD27				
Plugged under NDI 62350				

Date started 1/24/06 07, 20
Date complated 1/29/06 07, 20

7. WELL TEST DATA

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
300 gpm		3/6 hrs

8. WELL CONSTRUCTION
Depth Drilled 400' Feet Depth Cased 400' Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12 3/4 Inches	1 Feet	400' Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	17.	188	1	400'

Perforations:
Type perforation Mill Perforations
Size perforation 1/8 x 2 1/2 x 12# rows perf
From 300 feet to 400' feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 60'
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 60 feet to 400' feet

9. WATER LEVEL
Static water level 25' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature C °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Leach Drilling Inc (Contractor)
Address PO. 589 (Contractor)
SS NV 89429

Nevada contractor's license number issued by the State Contractor's Board 0031841
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1876

Signed [signature]
By driller performing actual drilling on site or contractor
Date 1/29/06

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627