WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 103086
Permit No.
Basin 207

NOTICE OF INTENT NO. 56048

1. OWNER Richard Holland
MAILING ADDRESS Po Box 261
Lund, NV 89317

ADDRESS AT WELL LOCATION
100 N 6 E Lot 6 Block 8
NAD27-N 38°51' 34.3" W 115° 00' 18.4"

2. LOCATION SW ¼ NE ¼ Sec. 33 T 12 N/S R 62 E White Pine County
PERMIT NO. N/A Issued by Water Resources
006-022-09 Parcel No.
Lund town Plat Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☒ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Silty top Soil		0	2.5	
gravel		2.5	3	
Clay Silt		3	9	
gravel		9	10	
Clay conglomerate		10	19	
gr		19	20	
Clay Conglomerate		20	30	
gravel-clay-con.		30	55	
gravel	water	55	65	10
Silty clay		65	76	
gravel	water	76	77	1
Clay		77	89	
gravel	water	89	85	1
Clay conglomerate		85	90	
gravel	water	90	92	2
Clay conglomerate		92	100	

N 38.859806
W 115.005111 NAD27

Date started Jan 15 ~~19~~ 2007
Date completed Feb 8 ~~19~~ 2007

7. WELL TEST DATA
TEST METHOD: ☒ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30	25	16

2007 FEB 23 AM 11:24

8. WELL CONSTRUCTION
Depth Drilled 100 Feet Depth Cased 100 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12 Inches		0 Feet	50 Feet
8 Inches		50 Feet	70 Feet
6 Inches		70 Feet	100 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.9	.188	-1	100

Perforations:
Type perforation Mill
Size perforation 2.5 x 5/8 x 6 row
From 60 feet to 100 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☒ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 70 feet

9. WATER LEVEL
Static water level 38 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Maynard Well Drilling Contractor
Address Po Box 69 Lund NV 89317 Contractor

Nevada contractor's license number issued by the State Contractor's Board 047224
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1556
Signed Orvan Maynard By driller performing actual drilling on site or contractor
Date Feb 21-07

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627