STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 103087
Permit No.
Basin 648

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 56168

1. OWNER Christine Meyers
MAILING ADDRESS 1450 Rancho
Fernley, Nv 89408

ADDRESS AT WELL LOCATION 881 Lovelock Street
Subdivision Name: County: Elko

2. LOCATION SW ¼ SE ¼ Sec 16 T 34N N/S R 56 E
PERMIT/WAIVER No. 013-031-012
Issued by Water Resources Parcel No.

Latitude 40.92598N
Longitude 115.66728W
UTM E N
☐ NAD 27 ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition ☐ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test ☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC ☐ Air ☐ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sub-soil		0	4	4
Tan Colored Clay		4	23	19
Sand & Gravel		23	63	60
Blue Clay		63	261	198
Fine Sand/Small Gravel	X	261	284	23

N40.926073
W 115.666373 NAD27

Date started: 14-Jun, 20 06
Date completed: 17-Jun, 20 06

9. WELL CONSTRUCTION
Depth Drilled 284 Feet Depth Cased 284 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10	Inches	0	Feet	284	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	12.92	188	+1	20
6		SDR-17	20	284

Perforations:
Type of perforation screen
Size of perforation 0.032
From 264 feet to 284 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☐ Yes ☒ No
☐ Neat Cement to ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☒ Concrete Grout 0 to 20 ☐ Pumped ☒ Poured
☒ ≥30% Bentonite Grout 20 to 56 ☒ Pumped ☐ Poured
Gravel Pack: ☒ Yes ☐ No 56 to 284 ☐ Pumped ☒ Poured
Type: 3/8 PEA GRAVE;
Bentonite Chips: ☐ Yes ☐ No to ☐ Pumped ☐ Poured
Type:

7. Water Level
Static water level: 63 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
APPROX	25		12.6

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name SHAREL C. FERTIG SR. dba FERTIG DRILLING COMPANY
Contractor
Address P.O. BOX 525
Contractor
ELKO, NV 89803
Nevada contractor's license number issued by the *State Contractor's Board* 031904
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 1584
Signed
By driller performing actual drilling on site or contractor
Date 2-19-07

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY