COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 103088
Permit No.
Basin 163

NOTICE OF INTENT NO. 58238

1. OWNER CARSON COUNTRY CONSTRUCTION
MAILING ADDRESS 5524 SIERRA VISTA LANE
CARSON CITY, NV 89701

ADDRESS AT WELL LOCATION 5005 SIERRA VISTA LN
CARSON CITY, NV 89701

2. LOCATION ~~SE~~ ¼ ~~SW~~ ¼ Sec 35 T 15 N R 20 E CARSON County
PERMIT NO. SW NE (Issued by Water Resources) | 010-121-21 (Parcel No.) | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
BROWN DG SANDS		0	9	9
BROWN CLAY		9	37	28
COURSE OBSIDIAN SANDS		37	92	55
BLACK HARD VOLCANIC SAND	X	92	248	156
GRAY CLAY		248	310	62
FRACTURED SANDS VOLCANIC GRAVELS	XX	310	340	30

N 39.122462
W 119.700883 NAD27

GPS INFO: NAD 83
39.12236*N
119.70188*W

Date started 1/25, 20 07
Date completed 1/31, 20 07

7. WELL TEST DATE

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
12	120	3 HRS

2007 FEB 23 AM 11:25

8. WELL CONSTRUCTION
Depth Drilled 340 Feet Depth Cased 340 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 3/4 Inches	0 Feet	140 Feet
6 1/8 Inches	140 Feet	340 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	+2	140
5	11.86	.188	130	340

Perforations:
Type perforation FACTORY MILL SLOT
Size perforation
From 120 feet to 140 feet
From 280 feet to 300 feet
From 320 feet to 340 feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No Seal Type:
Depth of Seal 100 ☐ Neat Cement
Placement Method: ☒ Pumped ☒ Cement Grout
☐ Poured ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 100 feet to 140 feet

9. WATER LEVEL
Static water level 65 feet below land surface
Artesian flow G.P.M P.S.I
Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name CAPITAL CITY WELL DRILLING (CONTRACTOR)
Address 20 KIT KAT DRIVE (CONTRACTOR)
CARSON CITY, NV 89706
Nevada contractor's license number issued by the State Contractor's Board 0055548
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905
Signed [signature]
By driller performing actual drilling on site or contractor
Date 2/21/07