COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 103089
Permit No.
Basin 104

PRINT OR TYPE ONLY

Bob Polichio

NOTICE OF INTENT NO. 58242

1. OWNER MARTY VANATA CONSTRUCTION
MAILING ADDRESS 3355 Idlewild DR Reno NV 89509
CARSON CITY, NV 89701

ADDRESS AT WELL LOCATION 1390 VALLEY VIEW DR
CARSON CITY, NV 89701

2. LOCATION ~~SE~~ ¼ ~~NW~~ ¼ Sec 29 T 15 N R 20 E CARSON County

PERMIT NO.			
NE	SE	009-332-06	
Issued by Water Resources		Parcel No.	Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other N/A

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
OLD 6 5/8 WELL 105'		0	105	105
PULLED PUMP OUT				
CLEANED OUT TO				
BOTTOM OF WELL				
PERFORATED FROM				
38' TO 90' 4 ROWS				
2' APART				
THEN PUMPED WITH 2				
YRDS NEAT CEMENT				
TO SURFACE FROM				
BOTTOM				
N 39.132963				
W 119.752401 NAD27				
GPS INFO: NAD 83				
39.13236*N				
119.75340*W				

Date started 2/14, 20 07
Date completed 2/15, 20 07

7. WELL TEST DATE

TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
N/A	N/A	N/A

2007 FEB 23 AM 11:25

8. WELL CONSTRUCTION

Depth Drilled N/A Feet Depth Cased N/A Feet

HOLE DIAMETER (BIT SIZE)

	From	To
6 5/8 Inches	0 Feet	105 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.34	.156	0	105

Perforations:
Type perforation N/A
Size perforation N/A
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☐ No Seal Type:
Depth of Seal N/A ☐ Neat Cement
Placement Method: ☐ Pumped ☐ Cement Grout
☐ Poured ☐ Concrete Grout
Gravel Packed: ☐ Yes ☐ No
From N/A feet to N/A feet

9. WATER LEVEL
Static water level 88 feet below land surface
Artesian flow G.P.M N/A P.S.I
Water temperature COLD °F Quality N/A

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name CAPITAL CITY WELL DRILLING (CONTRACTOR)
Address 20 KIT KAT DRIVE (CONTRACTOR)
CARSON CITY, NV 89706
Nevada contractor's license number issued by the State Contractor's Board 0055548
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905
Signed [signature]
By driller performing actual drilling on site or contractor
Date 2/21/07