WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 103092
Permit No.
Basin 099

NOTICE OF INTENT NO. 52995

1. OWNER Chuck Nay
MAILING ADDRESS 55 Clydesdale Dr. Reno NV 89506
ADDRESS AT WELL LOCATION 55 Clydale Dr Reno NV 89506

2. LOCATION NE ¼ ~~SW~~ ¼ Sec. ~~33~~ 32 T 24 ~~N~~/S R 18 E Washoe County
PERMIT NO. SE (Issued by Water Resources) 078 302 28 (Parcel No.) Rancho Havin (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	2	2
Sand		2	15	13
Clay		15	17	2
Sand & Clay layer		17	175	158
Clay		158	179	21
Sand		179	203	24
Clay		203	206	3
Sand		206	218	12
Clay		218	220	2
N 39.90160				
W 119.98016	NAD83			
N 39.901716				
W 119.979144	NAD27			

Date started 1/26, 20 07
Date completed 2/8, 20 07

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
50	215	4

8. WELL CONSTRUCTION
Depth Drilled 220 Feet Depth Cased 220 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
18 Inches	0 Feet	15 Feet
11 Inches	15 Feet	220 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.9	3/16	0	220

Perforations:
Type perforation Saw slot
Size perforation 3/16
From 180 feet to 220 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 100'
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 100 feet to 220 feet

9. WATER LEVEL
Static water level feet below land surface
Artesian flow Yes G.P.M. 5 P.S.I.
Water temperature NA °F Quality NA

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Olenski Drilling & Pump Co (Contractor)
Address 15045 Red Rock Rd (Contractor)
Reno NV. 89506
Nevada contractor's license number issued by the State Contractor's Board 50343
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1656
Signed (By driller performing actual drilling on site or contractor)
Date 2/8/07

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627