STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 103094
Permit No.
Basin 045

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 59024

1. OWNER DOUG WRIGHT
MAILING ADDRESS 500 COMMERCIAL STREET
ELKO, NV 89801

ADDRESS AT WELL LOCATION
Subdivision Name: PARCEL OF LAND County: ELKO

2. LOCATION SW ¼ SE ¼ Sec 10 T 33N N/S R 57 E
PERMIT/WAIVER No. 006-520-018
Issued by Water Resources Parcel No.

Latitude
Longitude
UTM E 11T 623881 ☐ NAD 27
N 4512259 ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOP SOIL		0	2	2
CLAY BROWN		2	30	28
BROWN SILTSTONE		30	110	80
SAND & SMALL GRAVEL	140	110	160	50

N 40.753868
W 115.532516 NAD27

Date started: 22-Jan, 20 07
Date completed: 24-Jan, 20 07

9. WELL CONSTRUCTION
Depth Drilled 160 Feet Depth Cased 160 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10-5/8	Inches	0	Feet	160	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6-5/8	13	.188	+1	160

Perforations:
Type of perforation MILL SLOT
Size of perforation 3/16x3
From 140 feet to 160 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☒ Neat Cement 5 to 15 ☐ Pumped ☒ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured

Gravel Pack: ☒ Yes ☐ No 50 to 160 ☐ Pumped ☒ Poured
Type: PEA GRAVEL
Bentonite Chips: ☒ Yes ☐ No 15 to 50 ☐ Pumped ☒ Poured
Type: 3/8 CHIPS

7. Water Level
Static water level: 111 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: COLD °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25		8

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name HACKWORTH DRILLING, INC. (Contractor)
Address P. O. BOX 850 (Contractor)
ELKO, NV 89803
Nevada contractor's license number issued by the *State Contractor's Board* 020582
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 1689
Signed (By driller performing actual drilling on site or contractor)
Date 1/31/2007

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY