38° 46.017 N 115° 03.176 W WGS84

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 103096
Permit No.
Basin 207

NOTICE OF INTENT NO. 59392

1. OWNER Eagle Exploration
MAILING ADDRESS P.O. Box 10350, Reno, NV 89510
ADDRESS AT WELL LOCATION Hwy 318, Lund, NV
Local No 207N10E6231Cb.

2. LOCATION NW ¼ SW ¼ Sec. 31 T. ~~10~~ 11 N/S R. 62 E. Nye County
PERMIT NO. MM-141A (Issued by Water Resources) | 207N10E6231Cb (Parcel No.) | Subdivision Name
Waiver

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Lime Stone		1	47	
Cobble				
Clay lay		49	56	
Lime Stone Cobble				
w/ Clay lay		56	246	
Clay		246	253	
Lime Stone Cobble		253	396	
Some Clay layers				
(Broke Lime Stone "Cobble")				
N 38.767009				
W 115.052070 NAD27				

Date started 3/26/07, 20
Date complated 3/28/07, 20

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
70		5 1/2

STATE ENGINEER'S OFFICE
2007 APR 11 AM 10:59
RECEIVED

8. WELL CONSTRUCTION
Depth Drilled 396 Feet Depth Cased 396 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 Inches	1 Feet	60 Feet
8 5/4 Inches	60 Feet	396 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13	1.88	1	396

Perforations:
Type perforation Mill Perf
Size perforation 1/8 x 2 1/2 x 11 rows per
From 236 feet to 256 feet
From 316 feet to 336 feet
From 376 feet to 396 feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 60'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 60 feet to 396' feet

9. WATER LEVEL
Static water level 136' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature C °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Lesser Drilling Inc (Contractor)
Address P.O. Box 598 (Contractor)
SS NV 89428
Nevada contractor's license number issued by the State Contractor's Board 0031841
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1896
Signed [signature] By driller performing actual drilling on site or contractor
Date 3/4/07

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627