COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 103098
Permit No.
Basin 105

NOTICE OF INTENT NO. 58231

1. OWNER MIKE WALTERS CONSTRUCTION
MAILING ADDRESS 770 BUCKSKIN LN
GARDNERVILLE , NV 0410

ADDRESS AT WELL LOCATION 770 BUCKSKIN LN
GARDNERVILLE, NV 89410

2. LOCATION NW ¼ NW ¼ Sec 19 T 12 N R 21 E DOUGLAS County

PERMIT NO. (Issued by Water Resources) 1221-19-001-002 (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
BROWN CLAY		0	3	3
COURSE GRAVELS		3	36	33
GRAVELS		36	78	42
BROWN CLAY		78	130	52
SMALL SILTY SANDS		130	187	57
BROWN GUMMY CLAY		187	211	24
FRACTURED GRAVELS	XXX	211	260	49

GPS INFO: NAD 83
38.89384*N
119.67640*W

N38.893938
W119.675407 NAD27

RECEIVED 2007 APR -3 AM 11:08 STATE ENGINEERS OFFICE

Date started 3/1 , 20 07
Date completed 3/5 , 20 07

7. WELL TEST DATE

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25	55	3 HRS

8. WELL CONSTRUCTION

Depth Drilled 260' Feet Depth Cased 260 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
11 Inches	0 Feet	260 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	1303	.188	+2	20
6 5/8 sdr21	4.06	.218	20	260

Perforations:
Type perforation SAW CUT
Size perforation 3 X 3/32
From 220 feet to 260 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 60
Placement Method: ☐ Pumped ☒ Poured
Gravel Packed: ☒ Yes ☐ No
From 60 feet to 260 feet

Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

9. WATER LEVEL
Static water level 95 feet below land surface
Artesian flow G.P.M P.S.I
Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name CAPITAL CITY WELL DRILLING (CONTRACTOR)
Address 20 KIT KAT DRIVE (CONTRACTOR)
CARSON CITY , NV 89706
Nevada contractor's license number issued by the State Contractor's Board 0055548
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905
Signed [signature] By driller performing actual drilling on site or contractor
Date 4/2/07