

STATE OF NEVADA
 DIVISION OF WATER RESOURCES

OFFICE USE ONLY

Log No. 103102
 Permit No. 1091
 Basin 1091
 NOTICE OF INTENT NO. 59090

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

'WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Boomtown Hotel & Casino ADDRESS AT WELL LOCATION South Verdi Rd. Well
 MAILING ADDRESS P.O. Box 399 #MW4
Verdi, NV 89439

2. LOCATION NW 1/4 NW 1/4 Sec. 16 T 19N N/S R 18E E Washoe County
 PERMIT NO. M10504 Issued by Water Resources Parcel No. 038-100-26 Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
On this date we pulled the monitor pump from the well and placed tremie to bottom at about 42'. We then pumped approximately 8 sacks of neat cement mixed 5.2 gal/sack from bottom to surface. We then cut the top 2' off of the 8" conductor casing and 5" well casing.				
Washoe County Permit #WL070021				
NAD83				
N39.51807				
W119.97272				
RECEIVED 2007 MAR 30 AM 11:36 STATE ENGINEERS OFFICE				
N39.518181				
W 119.972710 NAD 27				

8. WELL CONSTRUCTION
 Depth Drilled 42 Feet Depth Cased 42 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 Inches	0 Feet	30 Feet
8 Inches	30 Feet	42 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5"	10.79	.188	+1	42

Perforations:
 Type perforation Factory
 Size perforation 3/32 x 3"

From	To
17 feet	37 feet
feet	feet
feet	feet
feet	feet
feet	feet

Surface Seal: Yes No
 Depth of Seal 12.5' Seal Type: Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 12 feet to 42 feet

9. WATER LEVEL
 Static water level 26 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality Not tested

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Bruce MacKay Pump & Well Service, Inc. Contractor
 Address 1600 Mt. Rose Hwy Contractor
Reno, NV 89511
 Nevada contractor's license number issued by the State Contractor's Board 23096
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2299

Signed R. Bruce MacKay
 By driller performing actual drilling on-site or contractor
 Date 3/16/2007

Date started 3/16/2007 19
 Date completed 3/16/2007 19

7. WELL TEST DATA

TEST METHOD:	Bailer	Pump	Air Lift
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	