

STATE OF NEVADA
 DIVISION OF WATER RESOURCES

OFFICE USE ONLY
 Log No. 103105
 Permit No. _____
 Basin 42A

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **59099**

1. OWNER Jared Krupa
 MAILING ADDRESS 3450 Gwynelle Ct. Sparks, NV 89431
 ADDRESS AT WELL LOCATION 11566 Osage Rd.

2. LOCATION NE 1/4 NE 1/4 Sec. 24 T 21N N/S R 18E E Washoe County
 PERMIT NO. 086-231-11 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	1	1
Brown sandy gravels		1	8	7
Granite sands gravel		8	20	12
Brown sandy clay some granite		20	83	63
Bolder		83	84	1
D.G.		84	88	4
Brown sandy clay		88	131	43
Soft zone		131	136	5
Brown sandy clay		136	184	48
Soft zone		184	188	4
Brown sandy clay		188	191	3
Soft zone		191	203	12
Brown sandy clay		203	230	27
Soft zone	X	230	232	2
Brown sandy clay		232	239	7
Soft zone	X	239	247	8
Brown sandy clay		247	265	18
Soft zone	X	265	271	6
Brown sandy clay		271	280	9

Washoe County Permit # WL060071
 Nad 83
 N 39.67736
 W 119.90540

N 39.67736
W 119.90540 NAD 83

8. WELL CONSTRUCTION
 Depth Drilled 280 Feet Depth Cased 280-280 Feet
 HOLE DIAMETER (BIT SIZE)

10 5/8	Inches	From 0	Feet	To 50	Feet
8.5	Inches	50	Feet	280	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	+2	280

Perforations:
 Type perforation Machine cut
 Size perforation 3/32 x 3
 From 180 feet to 200 feet
 From 230 feet to 270 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No
 Depth of Seal 50
 Placement Method: Pumped Poured
 Seal Type: Neat Cement Cement Grout Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 280 feet

9. WATER LEVEL
 Static water level 70 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature Cool °F Quality Not tested

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Bruce Mackay Pump & Well Service, Inc. Contractor
 Address 1600 Mt. Rose Hwy Contractor
Reno, NV 89511
 Nevada contractor's license number issued by the State Contractor's Board 23096
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
 Signed R. Bruce Mackay
 By driller performing actual drilling on-site of contractor
 Date 3/28/2007

7. WELL TEST DATA

TEST METHOD:	Bailer	Pump	Air Lift
	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	

25 STATE ENGINEERS OFFICE
 3
 2007 MAR 30 AM 11:36
 RECEIVED