

Log No. 103100  
 Permit No. \_\_\_\_\_  
 Basin 207

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 56049

1. OWNER Dusty Keppner ADDRESS AT WELL LOCATION HWY 318  
 MAILING ADDRESS PO Box 150 294 NAD 27 N 38° 52' 43.61" 1/2 Lot C Blk 17  
Ely NV 89301 W 115° 00' 55.0" HWY 318

2. LOCATION NW 1/4 NW 1/4 Sec 28 T 12 N 12 R 62 E White Pine County  
 PERMIT NO. N/A 013-084-09 Parcel No. Land ten acre plat Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Silty top soil		0	5	
Silty clay		5	9	
gravel conglomerate		9	11	
clay con.		11	15	
gravel clay con.		15	25	
clay con.		25	30	
gravel con		30	50	
clay con		50	59	
gravel	water	59	70	
clay		70	80	
gravel con	water	80	90	
clay		90	100	
gravel	water	100	105	
Sandy clay		105	150	
gravel	water	150	155	
clay		155	170	

RECEIVED  
 2007 MAR 29 AM 11:12  
 STATE ENGINEERS OFFICE

N 38.8 78778  
 W 115 05278  
 115 NAD 27

8. WELL CONSTRUCTION  
 Depth Drilled 170 Feet Depth Cased 170 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	To	Feet	Feet
10	0	50		
8	50	90		
6	90	170		

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 7/8	12.9	.188	-1	170

Perforations:  
 Type perforation MILL  
 Size perforation EX 2 1/2 x 6 Row

From	To	From	To
70	90	90	90
110	130	130	130
150	170	170	170

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout

Depth of Seal 50

Placement Method:  Pumped  Poured

Gravel Packed:  Yes  No  
 From 50 feet to 90 feet

9. WATER LEVEL  
 Static water level 51 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature Cold °F Quality good

Date started Feb 9 2007  
 Date completed March 9 2007

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input checked="" type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift	<u>45</u>	<u>20</u>	<u>1 hr.</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Maynard Well Drilling Contractor  
 Address PO Box 64 Land NV 89317 Contractor

Nevada contractor's license number issued by the State Contractor's Board 047224  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1556

Signed Maynard  
 By driller performing actual drilling on site or contractor  
 Date March 29 - 07