STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 10308
Permit No.
Basin 100

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form it its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 58409

1. OWNER: Woodland Village North LLC
MAILING ADDRESS: PO Box 7548
SE SW Reno, NV 89510

ADDRESS AT WELL LOCATION: Sweger Well
Saw Tooth Court

2. LOCATION ~~SW~~ ¼ ~~SE~~ ¼ Sec 9 T 21N N/S R 18 E
PERMIT/WAIVER No 74135/WL070014 556-29C-16
Issued by Water Resources Parcel No

Latitude N39.69680
Longitude W119.97035
UTM E
N
☒ NAD 27 ☐ NAD 83/WGS 84
Subdivision Name County Washoe

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other.....

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☒ RVC
☐ Air ☐ Other .....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Surface clay		0	10	10
Sandy clay		10	140	130
Cobbles		140	150	10
Sand and clay		150	160	10
Brown clay		160	180	20
Sandy clay		180	195	15
Gravel		195	205	10
Sandy clay		205	230	25
Clay		230	240	10
Sandy clay		240	245	5
Basalt w/some clay		245	250	5
Gravel		250	255	5
Basalt w/some clay		255	285	30
Bed rock		285	305	20

RECEIVED 2007 MAR 26 PM 1:35 STATE ENGINEERS OFFICE

Date started 2/19/2007 , 20
Date completed 2/26/2007 , 20

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
100		24

8. WELL CONSTRUCTION
Depth Drilled 305 Feet Depth Cased 300 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
38	Inches	0	Feet	100	Feet
28	Inches	100	Feet	305	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
16		.375	+2	190
16		.375	290	300
30		.500	+1	100

Perforations
Type of perforation Screen
Size of perforation 0.04
From 190 feet to 290 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 100
Placement Method: ☒ Pumped ☐ Poured
Gravel Packed: ☒ Yes ☐ No
From 0 feet to 305 feet

Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

9. WATER LEVEL
Static water level 70 feet below land surface
Artesian flow G.P.M P.S.I
Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Hydro Resources Nevada, Inc dba Humboldt Drilling & Pump
Contractor
Address 4975 W. Winnemucca Blvd. Winnemucca, NV 89445
Contractor
Nevada contractor's license number issued by the *State Contractor's Board* 56797
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 1713
Signed Judi Leach Office
By driller performing actual drilling on site or contractor
Date 3/20/2007

(Rev. 12-06)

USE ADDITIONAL SHEETS IF NECESSARY