

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 10311
 Permit No. _____
 Basin 057

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **58651**

1. OWNER **Regional Transportation Commission**
 MAILING ADDRESS **P.O. Box 30002**
Reno, NV 89520

ADDRESS AT WELL LOCATION **1421 Victorian Ave.**
Sparks, NV.

2. LOCATION **NW** 1/4 **NWNE** 1/4 Sec. **8** T **19N**
 PERMIT NO. _____
 Issued by Water Resources _____ Parcel No. **032-171-30**

N/S R **20E** E _____ **Washoe** County
 Subdivision Name _____

3. WORK PERFORMED
 New Well
 Replace
 Recondition
 Deepen
 Abandon
 Other _____

4. PROPOSED USE
 Domestic
 Municipal/Industrial
 Irrigation
 Monitor
 Test
 Stock

5. WELL TYPE
 Cable
 Rotary
 RVC
 Air
 Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Well #1, 2" pvc well. Measured static water level at 16' and depth of well at 29'. Installed 28' of tremme pipe, mixed neat cement and pumped in from bottom of well to surface. 39° 28.267 N 119° 45.637 W				
Well #2, 2" pvc well. Measured static water level at 15.8" and depth of well at 29'. Installed 28' of tremme pipe, mixed neat cement and pumped in from bottom of well to surface. 38° 32.078 N 119° 45.705 W				
Well #3, 2" pvc well. Measured static water level at 15.9" and depth of well at 29.3'. Installed 28' of tremme pipe, mixed neat cement and pumped in from bottom of well to surface. 37° 30.782 N 119° 45.225 W				
All 3 wells required approximately 6 bags of Portland cement with 30 gallons of water.				
RECEIVED 2007 MAR 27 AM 10:50 STATE ENGINEERS OFFICE				
Well #1 N 39.534859 W 119.759612 NAD83 Well #2 N 39.634742 W 119.760745 NAD83 Well #3 37.30782 N 119.45225 W				

8. WELL CONSTRUCTION
 Depth Drilled n/a Feet Depth Cased **29'** Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	To	Feet
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2"	pvc	sch. 40	gl	29'

Perforations:
 Type perforation _____
 Size perforation _____
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No
 Depth of Seal **29'**
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level **16' average** feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name **Carson Pump** Contractor
 Address **P.O. Box 20159** Contractor
Carson City, NV. 89721

Nevada contractor's license number issued by the State Contractor's Board **39920**
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller **1482**
 Signed Don Stange
 By driller performing actual drilling on-site or contractor
 Date **3/11/2007**

Date started **2/22/2007**, 19
 Date completed **2/22/2007**, 19

7. WELL TEST DATA

TEST METHOD:	G.P.M.		Time (Hours)
	Draw Down (Feet Below Static)		
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			