38° 41.501N / 119° 19.992W

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 103114
Permit No.
Basin 107

NOTICE OF INTENT NO. 56932

1. OWNER Paul Stopple
MAILING ADDRESS Willington NV 17 Desert Creek
ADDRESS AT WELL LOCATION 17 Desert Creek

2. LOCATION NE ¼ NE ¼ Sec. 31 T. 10 N/S R. 24 E. Lyon County
PERMIT NO. Issued by Water Resources | 10-751-08 Parcel No. | Smith Valley Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☒ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Boulders Cobbles		1	183	
Clay, Cobbles		183	215	
Cobble Boulder		215	425	
Clay Cobbles		425	463	
Cobble Boulders		463	614	
Clay		614	624	
Cobbles/W Clay layers Volcanic		624	806	
Volcanic Rock	X	(580-700)		
Fractures W Clay layers		806	913	
	X	(880-913)		
N 38.691775				
W 119.332219 NAD27				

Date started 2/1/07, 20
Date completed 2/18/07, 20

7. WELL TEST DATA

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
35-40		2hrs

STATE ENGINEERS OFFICE
2007 MAR 27 AM 10:47
RECEIVED

8. WELL CONSTRUCTION
Depth Drilled 913' Feet Depth Cased 913' Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 Inches	1 Feet	60' Feet
8 3/4 Inches	60 Feet	701' Feet
6' Inches	701 Feet	913' Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13	1.88	1	701'
5.00	10	1.88	693	913'

Perforations:
Type perforation Machine Perf
Size perforation 1/8 x 2 1/4 x 8# rows
From 580 feet to 620 feet
From 660 feet to 700 feet
From 5' 863 feet to 893 feet
From 813 feet to 823 feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 60'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 60 feet to 701' feet

9. WATER LEVEL
Static water level 489' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature W °F Quality Acceptable

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Jeach Drilling Inc Contractor
Address PO 599 Contractor
SQ NV 89429
Nevada contractor's license number issued by the State Contractor's Board 0031841
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1876
Signed By driller performing actual drilling on site or contractor
Date 2/18/07

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627