

MW-2

WHITE-DIVISION OF WATER RESOURCES
CANARY-CLIENT'S COPY
PINK-WELL DRILLER'S COPY



STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 103121
Permit No.
Basin 031

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 56925
390750 E 4830920 N

1. OWNER Golden Associate Inc ADDRESS AT WELL LOCATION UTM, NAD 27
MAILING ADDRESS 2580 Wyandott St, Ste 6
2. LOCATION NE NE 1/4 Sec 7 T. 35 S R. 33 E Humboldt County
PERMIT NO. M/0 1433 Issued by Water Resources Parcel No. 05-411-09 Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
5. WELL TYPE
 Cable Rotary RVC
 Air Other HSA

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Silty sand / yellowish		0	18	18'
Sandy silt / yellowish		18	24	6'
Silty sand / yellowish		24	31	7'
Clayey silt / lt brown		31	33	2'
Silty sand / lt brown		33	38	5'
Sand / lt brown		38	48	10'
Silty sand / lt brown		48	52	4'
Sandy silt / lt brown		52	57	5'
Sand / lt brown	wet	57	65	8'
Clayey silt / lt brown		65	68	3'
Silty sand / brown		68	75	7'
Sand silt / gray		75	77	2'
Claysilt / green gray		77	94	17'
Silty sand / green gray		94	98	4'
Clayey silt / dark gray		98	102	4'

8. WELL CONSTRUCTION
Depth Drilled 102 Feet Depth Cased 80 Feet
HOLE DIAMETER (BIT SIZE)
From 8 Inches To 102 Feet
CASING SCHEDULE
Size O.D. (Inches) Weight/Ft. (Pounds) Wall Thickness (Inches) From (Feet) To (Feet)
2" SCH 40 +3 60
Perforations:
Type perforation factory slot
Size perforation .020
From 60 feet to 80 feet
Surface Seal: Yes No Seal Type:
Depth of Seal 50 change from 50-55' Neat Cement
Placement Method: Pumped poured bentonite Cement Grout
 Poured change 80-102' Concrete Grout
Gravel Packed: Yes No
From 55 feet to 80 feet

Date started 1-08, 2007
Date completed 1-09, 2007

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet)
<input type="checkbox"/> Bailer <input checked="" type="checkbox"/> Pump <input type="checkbox"/> Air Lift		
<u>Development</u>		<u>30 min</u>
		<u>2007 MAR 23 AM 11:32</u>

RECEIVED

9. WATER LEVEL
Static water level 58.8 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature 58.5 °F Quality _____
10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Haz Tech Drilling Contractor
Address P.O. 940 Meadows Dr 83580 Contractor
Nevada contractor's license number issued by the State Contractor's Board 0038018
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-23A
Signed A. Schalle
By driller performing actual drilling on site or contractor
Date 3-2-07