

WHITE-DIVISION OF WATER RESOURCES
CANARY-CLIENT'S COPY
PINK-WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 103122
Permit No. _____
Basin. 83

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK



WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 56924

1. OWNER Golden Associates Inc ADDRESS AT WELL LOCATION 389350 E 4529500 N
MAILING ADDRESS 2580 Wyandotte St., Ste G UTAH, NAD 27

2. LOCATION S_W 1/4 SW 1/4 Sec 7 T. 35 S R. 33 E Humboldt County
PERMIT NO. MD 1433 Issued by Water Resources Parcel No. 05-411-09 Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
5. WELL TYPE
 Cable Rotary RVC
 Air Other HSA

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandy silt / yellowish		0	17	17'
Silty clay / yellowish		17	21	4'
Silty sand / lt grey		21	24	3'
Silty sand / lt brown		24	48	24'
Silty sand / dark brown		48	51	3'
Sand / dark grey	Wet	51	62	11'
Silty sand / lt brown		62	64	2'
Silty clay / grey brown		64	68	4'
Sand / dark grey		68	73	5'
Silty clay / dark grey		73	98	25'
Silty sand / grey		98	100	2'
Clayey silt / dark grey		100	103	3'

N40.911032
W 118.313855 NAD27

8. WELL CONSTRUCTION
Depth Drilled 103 Feet Depth Cased 76 Feet

HOLE DIAMETER (BIT SIZE)
From 0 To 103
Inches 8 Feet 103 Feet
Inches _____ Feet _____ Feet
Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2"		SCH 40	+3	76

Perforations:
Type perforation factory slot
Size perforation .20
From 66 feet to 76 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
Depth of Seal 60' chips from 60-64' Neat Cement
Placement Method: Pumped panel bulkhead chips from 76-103' Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
From 64 feet to 76 feet

9. WATER LEVEL
Static water level 60.5 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature 58.5 °F Quality _____

Date started 1-03, 20 07
Date completed 1-05, 20 07

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>Development</u>	<u>30 min</u>	<u>2007 MAR 23 AM 11:32</u>

RECEIVED

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Haz Tech Drilling Contractor
Address P.O. 940 Orderville Rd 83680 Contractor

Nevada contractor's license number issued by the State Contractor's Board 0038018
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-2312

Signed [Signature] By driller performing actual drilling on site or contractor
Date 3-2-07