

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO 56926
 ADDRESS AT WELL LOCATION 390750 E 4529550 N

1. OWNER Golden Associates Inc ADDRESS AT WELL LOCATION 390750 E 4529550 N
 MAILING ADDRESS 2580 Wyandotte St, Ste G UTM, NAD 27

2. LOCATION SE 1/4 SE 1/4 Sec 7 T. 35 N/S R. 33 E Humboldt County
 PERMIT NO. m. 62 1433 Issued by Water Resources | 05-411-09 Parcel No. | _____ Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other HSA

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Silty sand / yellowish		0	23	23'
Silty clay / yellowish		23	28	5'
Silty sand / lt brown		28	34	6'
Sand / brown		34	38	4'
Silty clay / yellowish brown		38	41	3'
Silty sand / yellowish brown		41	43	2'
Silty clay / lt brown		43	52	9'
Silty sand / lt brown yellow		52	54	2'
Silty sand / lt brown		54	58	4'
Sand / dark brown	West	58	71	13'
Clayey silt / dark grey		71	73	2'
Sand / dark grey		73	81	8'
Silty clay / green grey		81	93	12'
Silty sand / dark grey		93	96	3'
Sand / dark grey		96	98	2'
Silty clay / dark grey		98	100	2'
Silty sand / dark grey		100	102	2'

8. WELL CONSTRUCTION

Depth Drilled 102' Feet Depth Cased 80 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	To	Feet	Feet
<u>8</u>	<u>0</u>	<u>102'</u>		

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2"</u>		<u>Sch 40</u>	<u>+3</u>	<u>80</u>

Perforations:
 Type perforation factory slot
 Size perforation .020
 From 60 feet to 80 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 54' chips from 54-58' Neat Cement
 Placement Method: Pumped poured chips from 80-102' Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 58 feet to 80 feet

Date started 1-06, 2007
 Date completed 1-07, 2007

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>Development</u>	<u>30 min</u>	

STATE ENGINEERS OFFICE
 2007 MAR 23 AM 11:32
 RECEIVED

9. WATER LEVEL
 Static water level 61 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature 85 °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Har Tech Drilling Contractor
 Address PO 940 Humboldt Rd 83620 Contractor
 Nevada contractor's license number issued by the State Contractor's Board 0038018
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-2312
 Signed [Signature] By driller performing actual drilling on site or contractor
 Date 3-2-07