COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 103191
Permit No.
Basin 105

NOTICE OF INTENT NO. 58245

1. OWNER BEN HENCKLE
MAILING ADDRESS 1609 JONES STREET
MINDEN, NV 89423
ADDRESS AT WELL LOCATION 2426 MT COMO
GARDNERVILLE, NV 89410

2. LOCATION ~~SW~~ NW ¼ ~~SE~~ NW ¼ Sec 4 T 12 N R 21 E DOUGLAS County
PERMIT NO. Issued by Water Resources
Parcel No. 1221-04-001-~~011~~ 017
FISH SPRINGS Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
OVERBURDEN CLAY		0	3	3
LARGE GRAVELS		3	60	57
BROWN CLAY		60	110	50
GRAVELS				
SMALL SANDS		110	166	56
CLAY SEAMS				
BROWN CLAY SEAM		166	178	12
SILTY BROWN CLAY		178	200	22
CLAY SEAM		200	223	23
SMALL GRAVELS	XXX	223	260	37

N 38.933168
W 119.637007 NAD27

GPS Zone NAD 83
38.93907°N
119.63800°W

Date started 3/13, 20 07
Date completed 3/15, 20 07

7. WELL TEST DATE
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25+	65	3 HRS

RECEIVED
2007 APR 10 PM 3:35
STATE ENGINEER'S OFFICE

8. WELL CONSTRUCTION
Depth Drilled 260 Feet Depth Cased 260 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 3/4 Inches	0 Feet	260 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	+2	20
6 5/8 sdr21	4.06	.216	20	260

Perforations:
Type perforation FACTORY MILL SLOT
Size perforation 3 X 3/32
From 220 feet to 260 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 100
Placement Method: ☒ Pumped ☐ Poured
Gravel Packed: ☒ Yes ☐ No
From 100 feet to 260 feet
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

9. WATER LEVEL
Static water level 85' feet below land surface
Artesian flow G.P.M 25+ P.S.I
Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name CAPITAL CITY WELL DRILLING INC. (CONTRACTOR)
Address 20 KIT KAT DRIVE (CONTRACTOR)
CARSON CITY, NV 89706
Nevada contractor's license number issued by the State Contractor's Board 0055548
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2157
Signed [signature] / Rick Crane
By driller performing actual drilling on site or contractor
Date 4/4/07

Forms Provided by Forms-On-A-Disk, Inc. · Dallas, Texas · (214) 340-9429