COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 103146
Permit No.
Basin 105

NOTICE OF INTENT NO. 58246

1. OWNER DENNIS CLARK CONSTRUCTION
MAILING ADDRESS P.O. BOX 909
GARDNERVILLE, NV 89410

ADDRESS AT WELL LOCATION 2456 MT COMO
GARDNERVILLE, NV 89410

2. LOCATION ~~NW~~ ¼ ~~SE~~ ¼ Sec 4 T 12 N R 21 E DOUGLAS County

PERMIT NO. NE NW (Issued by Water Resources) | 1221-04-001-020 (Parcel No.) | FISH SPRINGS (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
OVERBURDEN CLAY		0	3	3
LARGE GRAVELS		3	68	65
BROWN CLAY		68	87	19
GRAVELS				
COURSE GRAVELS		87	156	69
CLAY SEAMS				
BROWN CLAY SEAM		156	225	69
FRACTURED GRAVELS	XXX	225	260	35

N 38.938808
W 119.632877 NAD27

GPS NAD 83,
38.93871 N
119.63387°W

Date started 3/9, 20 07
Date completed 3/13, 20 07

7. WELL TEST DATE

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25+	65'	3 HRS

RECEIVED
2007 APR 10 PM 3:35

8. WELL CONSTRUCTION
Depth Drilled 260 Feet Depth Cased 260 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 3/4 Inches	0 Feet	260 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	+2	20
6 5/8 sdr21	4.06	.216	20	260

Perforations:
Type perforation SAW CUT
Size perforation 3 X 3/32
From 220 feet to 260 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No Seal Type:
Depth of Seal 100 ☒ Neat Cement
Placement Method: ☒ Pumped ☐ Cement Grout
☐ Poured ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 100 feet to 260 feet

9. WATER LEVEL
Static water level 90' feet below land surface
Artesian flow G.P.M 25+ P.S.I
Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name CAPITAL CITY WELL DRILLING INC. (CONTRACTOR)
Address 20 KIT KAT DRIVE (CONTRACTOR)
CARSON CITY, NV 89706
Nevada contractor's license number issued by the State Contractor's Board 0055548
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905
Signed [signature] By driller performing actual drilling on site or contractor
Date 4/4/07

(Rev 3-91) USE ADDITIONAL SHEETS IF NECESSARY

Forms Provided by Forms-On-A-Disk, Inc. · Dallas, Texas · (214) 340-9429