WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 103157
Permit No.
Basin 102

NOTICE OF INTENT NO. 56947

1. OWNER LACEY YOUNG
MAILING ADDRESS 2350 E. 9th Street Silver Springs, NV 89429
ADDRESS AT WELL LOCATION 2350 E. 9th street Silver Springs NV 89429

2. LOCATION ~~SE~~ ¼ ¼ Sec 17 T 17N ~~N/S~~ R 25 E Lyon County
PERMIT NO. 9E SW (Issued by Water Resources) | 17-343-11 (Parcel No.) | Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand + Clay		0	60	60 ft
gray clay		60	120	60 ft
Black gravel + gray clay		120	180	60 ft
Sand + gravel		180	200	20 ft
Brown gravel + Course sand		200	240	40 ft
39° 19.924 N	WGS84			
119° 12.380 W				
N 39.332168				
W 119.205347 NAD27				

Date started 3-22-07, 20
Date completed 3-23-07, 20

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

G.P.M.	Draw Down (Feet Below Static)	(Hours)
20+		2 Hrs

8. WELL CONSTRUCTION
Depth Drilled 240 Feet Depth Cased 240 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From (Feet)	To (Feet)
10 5/8	0	240

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13	.185	+1	20
6		SDR 21	20	240

Perforations:
Type perforation Saw cut
Size perforation 1 3/16
From feet to feet
From 220 feet to 235 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 50 ft
Placement Method: ☑ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☑ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 50 feet to 240 feet

9. WATER LEVEL
Static water level 35 ft feet below land surface
Artesian flow NA G.P.M. NA P.S.I.
Water temperature Cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Leach Drilling (Contractor)
Address PO Box 599 Silver Springs NV 89429 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 0031841
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1878
Signed (By driller performing actual drilling on site or contractor)
Date 3-23-07

(Rev. 12-01)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627