(38°47.105 N 117°10.313 W) W6589

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

I

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 103164
Permit No.
Basin 137B

NOTICE OF INTENT NO. 56949

1. OWNER Sirena St James
MAILING ADDRESS 2561 CENTURY DRIVE, Carson City, NV 89706
ADDRESS AT WELL LOCATION Dome at Curvers, Unit SMKYVL, Round Mountain, NV

2. LOCATION SW ¼ NE ¼ Sec. 29 T. 11 N/S R. 43 E. NYE County
PERMIT NO. Issued by Water Resources | 10-371-15 Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Soil		1	6	
Gravels Cobbles		6	14	
Clay		14	24	
Cobble Gravels		24	63	
w/small clay layers		63	79	
Sand				
Gray Sand		63	79	
Gravel Cobb		79	90	
Cobbles		90	95	
Clay, Sand Gravel layers		95	100	
N38.785159				
W117.170961 NAD27				

Date started 4/3/07, 20
Date completed 4/4/07, 20

7. WELL TEST DATA

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25		3

GRATE ENGINEERING DIVISION
2007 APR 11 AM 10:59
RECEIVED

8. WELL CONSTRUCTION
Depth Drilled 100' Feet Depth Cased 100' Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 Inches	1 Feet	100' Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13	1.88	1	20
6 5/8	PVC	SH 40	20	100

Perforations:
Type perforation Saw Cut
Size perforation 1/8 x 2 x 3 Rows per
From 90 feet to 95 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☒ No
From feet to Ø feet

9. WATER LEVEL
Static water level 1+ feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Lane Drill Inc
Contractor
Address PO 599
Contractor
S.S. NV 89429

Nevada contractor's license number issued by the State Contractor's Board 0031841

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1876

Signed [signature]
By driller performing actual drilling on site or contractor

Date 4/4/07

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627