STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 103191
Permit No.
Basin 021

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 49343

1. OWNER Lee Conver
MAILING ADDRESS 3535 Lupine Dr. Winnemucca NV, 89445

ADDRESS AT WELL LOCATION Sunset Dr Winnemucca, NV 89445
Subdivision Name: County: Humboldt

2. LOCATION NE ¼ NW ¼ Sec 13 T 35 N/S R 37 E
PERMIT/WAIVER No. 13-523-09 (Issued by Water Resources) Parcel No.
Latitude 40.912831 Longitude 117.767002
UTM E 11 435407 N 4529152 [x] NAD 27 [ ] NAD 83/WGS 84

3. WORKED PERFORMED
[x] New Well [ ] Replace [ ] Recondition [ ] Deepen [ ] Other

4. PROPOSED USE
[x] Domestic [ ] Irrigation [ ] Test [ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [x] Rotary [ ] RVC [ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
top soil		0	3	3
cobbles with gravel	X	3	135	132
clay and gravel		135	165	30
cobbles with gravel	X	165	180	15

RECEIVED 2007 APR 17 AM 10:48 STATE ENGINEER'S OFFICE

Date started: 20-Mar, 20 07
Date completed: 26-Mar, 20 07

9. WELL CONSTRUCTION
Depth Drilled 180 Feet Depth Cased 180 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10.625	Inches	0	Feet	180	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6.625		.188	+2	180

Perforations:
Type of perforation: punched
Size of perforation: 1.250 x .188
From 160 feet to 180 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: [x] Yes [ ] No
[ ] Neat Cement to [ ] Pumped [ ] Poured
[ ] Cement Grout to [ ] Pumped [ ] Poured
[x] Concrete Grout 4 to 53 [ ] Pumped [x] Poured
[ ] ≥30% Bentonite Grout to [ ] Pumped [ ] Poured
Gravel Pack: [x] Yes [ ] No 53 to 180 [ ] Pumped [x] Poured
Type: 3/8 minus
Bentonite Chips: [ ] Yes [ ] No to [ ] Pumped [ ] Poured
Type:

7. Water Level
Static water level: 77 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: cool °F
Quality: good

8. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [x] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30		1

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name American Drilling & Pump Service (Contractor)
Address 3040 Callahan St Winnemucca, NV 89445 (Contractor)
Nevada contractor's license number issued by the *State Contractor's Board* 0020578
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 2208
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 4-11-2007

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY