WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 103198
Permit No.
Basin 137B

NOTICE OF INTENT NO. 56948

1. OWNER Peter Vogt
MAILING ADDRESS HC-60 Box 76005 Round Mtn, NV, ~~[illegible]~~
ADDRESS AT WELL LOCATION HC-60 Box 76005, ~~[illegible]~~ Round Mtn, NV, ~~[illegible]~~

2. LOCATION NW ¼ NW ¼ Sec. 3 T. 14N N/S R. 43 E. NYE Co County
PERMIT NO. Issued by Water Resources | 10-461-02 Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☒ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Boulders & D-G-		0	78'	78
D-G & Clay-Sand		78	241	163
Gravel & Clay	✓	241	300	59
Boulders. Clay Sand	✓	300	380	80'
GPS. N. 39° 06. [redacted] 519'				
W 117° 08. [redacted] 514'				WGS84
Elevation 5720 feet				
N 39.108731 W 117.140974 NAD27				

Date started March 21/07, 20
Date complated March 26/07, 20

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25-30	GPM	3 Hrs

STATE ENGINEERS OFFICE
2007 APR 24 AM 11:17
RECEIVED

8. WELL CONSTRUCTION
Depth Drilled 380' Feet Depth Cased 381' Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 Inches	0 Feet	260' Feet
6" Inches	260 Feet	380 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.5	.188	+1	20
6 5/8	SDR21		20	260
500		.188	230	380'

Perforations:
Type perforation Sawed
Size perforation 48 & 3"
From 240 feet to 260' feet
From feet to feet
From 300 feet to 380' feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 60'
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 60 feet to 260' feet

9. WATER LEVEL
Static water level 180' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality Turbid

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Leach Drilling Inc. Contractor
Address PO Box 597 Contractor
Johnson Springs NV 89429
Nevada contractor's license number issued by the State Contractor's Board 31841
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1740
Signed Nathaniel L. Leach
By driller performing actual drilling on site or contractor
Date 4/21/07

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627