REPORT NO. A07.16

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

LOG NO. 103211
PERMIT NO.
BASIN Ø83

NOTICE OF INTENT NO. 58772

1. OWNER Karen Roemmich
MAILING ADDRESS 1720 Eagle Dancer Lane, Reno NV 89521

ADDRESS OF WELL 19200 Rocky Rd
Highland Ranches, NV

2. WELL LOCATION SW 1/4 NW 1/4 SEC. 2 T 17 R 21 E Storey COUNTY

PERMIT NO ____ PARCEL NO 004-281-07 SUBDIVISION NAME ____

3. TYPE OF WORK
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Plug [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [X] Mud

6. LITHOLOGIC LOG

MATERIAL	STRATA	FROM	TO	THICKNESS
Black Rock & Clay		0	18	18
Broken Up Black Rock & Clay		18	55	37
Black Rock & Red Clay		55	90	35
Red & Black Rock With Brown Clay		90	115	25
Brown Clay & Black Rock		115	170	55
Green Rock & Clay		170	195	25
Brown Rock & Clay		195	220	25
Green & Brown Rock & Clay		220	250	30
Brown Rock & Clay		250	310	60
Multi Colored Rock & Clay		310	375	65
Multi Colored Rock		375	405	30
Black Rock		405	410	5
Black & Green Rock		410	470	60
Black & Red Rock		470	550	80
Multi Colored Rock		550	735	185
Black & Red Rock		735	795	60
Green & Brown Rock		795	850	55
Black & Green Rock		850	875	25
Black & Brown Rock		875	918	43

Notes: WGS-84 GPS: Latitude:N39 22.08 Longitude: W119 35.76
N39.364105
W 119.595002 NAD27

Date Started 02/09/2007 Date Completed 03/04/2007

7. WELL TEST DATA

TEST METHOD [ ] Bailer [ ] Pump [X] Air Develop

	GPM	DRAWDOWN	TIME (HRS)
	15		4

8. WELL CONSTRUCTION
Depth Drilled 918' Depth Cased 918'

HOLE DIAMETER (BIT SIZE)
10 5/8 Inches 0 Feet 50 Feet
8 1/2 Inches 50 Feet 705 Feet
7 7/8 Inches 705 Feet 918 Feet

CASING SCHEDULE

Size OD	Weight/Ft	Wall Thickness	From	To
6 5/8"	12.92	.188	918'	+2'

PERFORATIONS:
Type Perforation Factory Size Perforation 3/32 x 3
From 878 Feet to 918 Feet
From ____ Feet to ____ Feet
From ____ Feet to ____ Feet

SURFACE SEAL: [X] Yes [ ] No
Seal Depth 55'
PLACEMENT METHOD: [ ] Pumped [X] Poured

SEAL TYPE:
[ ] Neat Cement
[ ] Cement Grout
[X] Concrete Grout
[ ] Bentonite

GRAVEL PACKED: [X] Yes [ ] No
From 55 Feet to 918 Feet

9. WATER LEVEL
Static Water Level 460' Feet Below Land Surface
Artesian Flow ____ GPM ____ PSI
Water Temperature Cool F Quality Clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of m knowledge.

Name Aqua Drilling & Well Service, Inc.
Address 675 Edison Way
Reno, NV 89502

NV. CONTRACTOR'S LIC. NO. 15291 DRILLER'S LIC. NO. ON SITE 2275

Signed [signature]
By driller performing actual drilling on site or contractor

Dated 3.7.07