

COPIES TO  
 - DIVISION OF WATER RESOURCES  
 - CLIENT'S COPY  
 - WELL DRILLER'S COPY

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
 Log No. 103231  
 Permit No. \_\_\_\_\_  
 Basin 212

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 31349

1. OWNER FONTAINEBLEAU LAS VEAS LLC ADDRESS AT WELL LOCATION 2755 S LAS VEGA BLVD.  
 MAILING ADDRESS 2827 PARADISE RD LAS VEGAS, NV 89109

2. LOCATION SE 1/4 NE 1/4 Sec 09 T 21 S R 61 E CLARK County  
 PERMIT NO. DW1234 162-09-602-002 Fontainebleau  
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE DEWATER  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<b>Plug 7 -Dewater wells</b>				
<b>Depth 40'</b>				
<b>Casing 14"</b>				
<b>Static water level 15'</b>				
<b>Casing cut down to 20' remaining casing pulled and filled with 1 yard of 9 sack grout to surface of each well.</b>				
<b>WGS84</b>				
<b>N36 08. 182'</b>				
<b>W115 09. 555'</b>				

8. WELL CONSTRUCTION  
 Depth Drilled 40 Feet Depth Cased 40 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 24 Inches To 0 Feet 40 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 CASING SCHEDULE  

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>14"</u>				

Perforations:  
 Type perforation Machine  
 Size perforation 1/4"x2.5" long 16 around  
 From 20 feet to 40 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal \_\_\_\_\_  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 0 feet to 40 feet

9. WATER LEVEL  
 Static water level 15 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

Date started 8/8, 20 07  
 Date completed 8/21, 20 07

7. WELL TEST DATE

TEST METHOD:	<input type="checkbox"/> Bailer	<input type="checkbox"/> Pump	<input type="checkbox"/> Air Lift
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name ALLEN DRILLING INC.  
(CONTRACTOR)  
 Address 4015 WEST TOMPKINS AVE  
(CONTRACTOR)  
LAS VEGAS, NV 89103  
 Nevada contractor's license number issued by the State Contractor's Board 18916 & 18917  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller MPDEW2343  
 Signed Timothy Wiley  
 By driller performing actual drilling on site or contractor  
 Date August 23, 2007