

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S PLUGGING REPORT

OFFICE USE ONLY
Log No. 103309
Permit No. _____
Basin 212

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1 OWNER PAI Biadnok ADDRESS AT WELL LOCATION 5929 Duncan Drive NOTICE OF INTENT NO. 31077
MAILING ADDRESS Same as well location Las Vegas Nevada 89108
Subdivision Name Towopah Terrace County Clark

2 LOCATION SW 1/4 NW 1/4 Sec 12 T 20 N R 60 E Latitude N 36.225136 UTM E NAD 27
PERMIT (WAIVER NO) R-1375 138-12-210-011 Longitude W 115.224134 N NAD 83 (VGS 84)

3 TYPE OF WELL
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
Is this well being plugged because a replacement well was drilled? NO
Is there an existing well log? Yes
If yes, what is replacement well NO? _____
If yes, what is NDWR well log #? 53608

4 EXISTING WELL CONSTRUCTION
Depth Drilled 125 Feet Depth Cased 125 Feet

7 WELL PLUGGING PROCEDURE
Was well cleaned out to total depth? yes no
If well was not cleaned out to total depth, please explain why: Waived well inside building unable to insert tooling in well

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8" Id</u>		<u>10 Gauge</u>	<u>+ 6"</u>	<u>125'</u>

Was the well contaminated? yes no
Was the casing pulled? yes no
Was the casing over drilled? yes no
If casing was left in place, please show where additional perforations were made:
Additional Perforations:
Type of perforater used: Waived well unable to perforate

Existing Perforations:
Type of perforation UNKNOWN
Size of perforation 3/16" x 10"
From 75' feet to 125' feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

From _____ feet to _____ feet Number of perfs per linear foot _____
From _____ feet to _____ feet Number of perfs per linear foot _____
From _____ feet to _____ feet Number of perfs per linear foot _____
From _____ feet to _____ feet Number of perfs per linear foot _____
From _____ feet to _____ feet Number of perfs per linear foot _____
From _____ feet to _____ feet Number of perfs per linear foot _____

5 WATER LEVEL
Static water level 46.5 feet below land surface
Artesian flow No G.P.M. N/A P.S.I.
Water temperature unknown °F Quality unknown

8 WELL PLUGGING MATERIALS
Material Used
From Bottom feet to Surface feet Neat Cement Pumped Poured
From _____ feet to _____ feet Pumped Poured

6 Additional Notes or Comments
well inside building with limited access. cut 86" of pump + pipe into 3 sections to remove, unable to perforate. Apply + Receive waiver install temporary grout well from bottom up to surface. cut casing below building slab and patch at surface.

Neat Cement Fluid Weight _____ lbs/gal
Bentonite Grout _____ % bentonite
Date Started JUNE 12, 07
Date Completed JULY 13, 07

3 yards Neat Cement
could not pull casing.

9 DRILLER'S CERTIFICATION
This well was plugged and abandoned under my supervision and the report is true to the best of my knowledge.
Name WDC Exploration and wells Contractor
Address 570 Corinthian way Contractor
N. Las Vegas, Nevada 89030
Nevada contractor's license number 00128542
issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller ABDR-2317
Signed Dan Smith
By driller performing actual drilling on site or contractor
Date July 16, 2007

LAS VEGAS OFFICE