

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S PLUGGING REPORT

OFFICE USE ONLY
Log No. 103314
Permit No. _____
Basin 212

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in
accordance with NRS 534.170 and NAC 534.340

1 OWNER Thank + Cecilia Shepper ADDRESS AT WELL LOCATION 1594 Ringe Lane
MAILING ADDRESS Same as well location Las Vegas, Nevada 89156
Subdivision Name: PT 604 Lot 190 County: Clark

NOTICE OF INTENT NO. 31085

2 LOCATION NW 1/4 NW 1/4 Sec 28 T 20 N R 62 E Latitude N 36.18857 UTM E _____
PERMIT (WAIVER) No. R-1373 140-28-10-024 Longitude W 115.05929 N _____
Issued by Water Resources Parcel No. _____

3 TYPE OF WELL
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
Is this well being plugged because a replacement well was drilled? No
Is there an existing well log? YES
If yes, what is replacement well NOI? _____
If yes, what is NDWR well log #? 56962

4 EXISTING WELL CONSTRUCTION
Depth Drilled 250 Feet Depth Cased 250 Feet

7 WELL PLUGGING PROCEDURE
Was well cleaned out to total depth? yes no

EXISTING CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8</u>			<u>+1</u>	<u>250</u>

If well was not cleaned out to total depth, please explain why:
Dropped to Bottom of well due to pump cut and overhead power lines, unable to set-up out well

Was the well contaminated? yes no
Was the casing pulled? yes no
Was the casing over drilled? yes no

Existing Perforations:

Type of perforation	Size of perforation	From	feet to	feet
<u>Touch</u>	<u>3 1/2" X 6"</u>	<u>80</u>	<u>feet to</u>	<u>250</u> feet

Additional Perforations:
Type of perforator used: unable to mills knife

From	feet to	feet	Number of perfs per linear foot

5 WATER LEVEL
Static water level Unknown feet below land surface
Artesian flow N/A G.P.M. N/A P.S.I.
Water temperature Unknown °F Quality unknown

8 WELL PLUGGING MATERIALS

From	feet to	Material Used	<input checked="" type="checkbox"/> Pumped	<input type="checkbox"/> Poured
<u>+1</u>	<u>feet to</u>	<u>Bottom</u>	<u>feet neat cement</u>	<input checked="" type="checkbox"/> Pumped <input type="checkbox"/> Poured

6 Additional Notes or Comments
Unable to pull pump due to several overhead powerlines apply and receive waiver cut and drop pump. Install trimline to bottom, pump neat cement from bottom to surface cut casing below surface.

Neat Cement Fluid Weight _____ lbs/gal
Bentonite Grout _____ % bentonite
Date Started July 12 2007
Date Completed July 13 2007

pumped 5 yards neat cement

LAS VEGAS OFFICE

9 DRILLER'S CERTIFICATION
This well was plugged and abandoned under my supervision and the report is true to the best of my knowledge.
Name WDC Exploration and wells Contractor
Address 570 Corinthian Way Contractor
N. Las Vegas Nevada 89030
Nevada contractor's license number issued by the State Contractor's Board 00128592
Nevada driller's license number issued by the Division of Water Resources, the on-site driller ABDR-2317
Signed Dak By driller performing actual drilling on site or contractor
Date July 16, 2007