STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 103327
Permit No.
Basin 212

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 31424

1. OWNER Clark County Aviation
MAILING ADDRESS P.O. Box 11005
Las Vegas, Nv

ADDRESS AT WELL LOCATION McCarren Airport Terminal 3
5757 Wanye Newton Boulevard, Las Vegas, NV
Subdivision Name: County: CLARK

2. LOCATION NE ¼ NE ¼ Sec 34 T 21 S R 61 E
PERMIT/WAIVER No. DW-1243A 162-34-502-010
Issued by Water Resources Parcel No.

Latitude UTM E NAD 27
Longitude N x NAD 83/WGS 84

3. WORKED PERFORMED
X New Well Replace Recondition
Deepen x Other Dewatering Well

4. PROPOSED USE Dewater
Domestic Irrigation Test
Municipal/Industrial Monitor Stock

5. WELL TYPE
Cable Rotary RVC
Air x Other Auger Bucket

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Well # 7454				
N486499.5 E631363				
Clayey Gravel		0	3	
Caliche - white/hard		3	6	
Fat Clay-with sand, gravel		6	18	
Silty Clayey Sand - red,brown		18	21	
Clayey Gravel, cemented lenses		21	34	
Sandy Fat Clay, brown to tan		34	47	
Caliche - moderate cemented		47	49	
Caliche - hard		49	51	
Well #7455				
N486499.4 E631263				
Clayey Gravel		0	3	
Caliche - white/hard		3	6	
Fat Clay-with sand, gravel		6	18	
Caliche - white/hard		18	21	
Clayey Gravel, cemented lenses		21	34	
Sandy Fat Clay, brown to tan		34	47	
Caliche - moderate cemented		47	49	
Caliche - hard		49	51	

Date started: 23-Jun , 20 07
Date completed: 6/23/2007 , 20 07

9. WELL CONSTRUCTION
Depth Drilled 51' Feet Depth Cased 50' Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
24"	Inches	surface	Feet	50' BGL	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6.5	3.6	.280	0	20

Perforations:
Type of perforation machine slot
Size of perforation .032"

From	20	feet to	50	feet
From		feet to		feet
From		feet to		feet
From		feet to		feet
From		feet to		feet

Annular Seal: Yes X No

Neat Cement	to		Pumped	Poured
Cement Grout	to		Pumped	Poured
Concrete Grout	to		Pumped	Poured
≥30% Bentonite Grout	to		Pumped	Poured

Gravel Pack: X Yes No to Pumped X Poured
Type: pea gravel
Bentonite Chips: Yes X No to Pumped Poured
Type:

7. Water Level
Static water level: 25' feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: °F
Quality:

8. WELL TEST DATA
TEST METHOD: Bailer x Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Griffin Dewatering Corp
Contractor
Address 536 E. Maitland Street
Contractor
Ontario, Ca 91761
Nevada contractor's license number issued by the *State Contractor's Board* C-23 0031246
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* M-2264
Signed [signature]
By driller performing actual drilling on site or contractor
Date June 25, 2007

DCNR/DWR
RECEIVED
JUL 12 2007
LAS VEGAS OFFICE