

STATE OF NEVADA DIVISION OF WATER RESOURCES WELL DRILLER'S REPORT						OFFICE USE ONLY	
						Log No.	103339
						Permit No.	
						Basin	212
PRINT OR TYPE ONLY						Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340	
DO NOT WRITE ON BACK						NOTICE OF INTENT NO. 31425	
1. OWNER Clark County Aviation			ADDRESS AT WELL LOCATION McCarren Airport Terminal 3				
MAILING ADDRESS P.O. Box 11005 Las Vegas, Nv			5757 Wayne Newton Boulevard, Las Vegas, NV				
			Subdivision Name:		County: CLARK		
2. LOCATION <i>W/1/4 NW/4</i>		1/4 Sec 35	T 21	SR 61	E	Latitude	UTM E
PERMIT/WAIVER No. DW-1244A		162-35-101-018		Longitude		N	x NAD 83/WGS 84
Issued by Water Resources		Parcel No.					
3. WORKED PERFORMED			4. PROPOSED USE <i>Dewater</i>			5. WELL TYPE	
<input checked="" type="checkbox"/> New Well	<input type="checkbox"/> Replace	<input type="checkbox"/> Recondition	<input type="checkbox"/> Domestic	<input type="checkbox"/> Irrigation	<input type="checkbox"/> Test	<input type="checkbox"/> Cable	<input type="checkbox"/> Rotary
<input type="checkbox"/> Deepen	<input checked="" type="checkbox"/> Other	<input type="checkbox"/> Dewatering Well	<input type="checkbox"/> Municipal/Industrial	<input type="checkbox"/> Monitor	<input type="checkbox"/> Stock	<input type="checkbox"/> Air	<input checked="" type="checkbox"/> Other
6. LITHOLOGIC LOG				9. WELL CONSTRUCTION			
Material	Water Strata	From	To	Thick-ness	Depth Drilled	61' Feet	Depth Cased
					60' Feet		
Well # 7434					HOLE DIAMETER (BIT SIZE)		
N486497.7 E632963					From To		
Fill - gravelly clay					24"	Inches	surface
						Inches	Feet
Sandy lean clay						Inches	Feet
						Inches	Feet
Caliche - hard off white							Feet
							Feet
Sandy lean clay							Feet
							Feet
Fat Clay - w/gravels							Feet
							Feet
Caliche - hard off white							Feet
							Feet
Fat Clay - w/gravels partially cem							Feet
							Feet
Well #7435					CASING SCHEDULE		
N486500.6 E633863					Size O.D.	Weight/Ft.	Wall Thickness
					(Inches)	(Pounds)	(Inches)
							From To
							(Feet) (Feet)
Fill - gravelly clay					6.5	3.6	.280
							0 30
Sandy lean clay							
Caliche - hard off white							
Sandy lean clay							
Fat Clay - w/gravels							
Caliche - hard off white							
Fat Clay - w/gravels partially cem							
					Perforations:		
					Type of perforation	machine slot	
					Size of perforation	.032"	
					From	30	feet to 60
							feet
					From		feet
							feet
					From		feet
							feet
					From		feet
							feet
					Annular Seal:	Yes	X No
					Neat Cement	to	Pumped
							Poured
					Cement Grout	to	Pumped
							Poured
					Concrete Grout	to	Pumped
							Poured
					≥30% Bentonite Grout	to	Pumped
							Poured
					Gravel Pack:	X Yes	No
							to
							Pumped
							X Poured
					Type:	pea gravel	
					Bentonite Chips:	Yes	X No
							to
							Pumped
							Poured
					Type:		
7. Water Level					10. DRILLER'S CERTIFICATION		
Static water level: 33 feet below land surface					This well was drilled under my supervision and the report is true to the best of my knowledge.		
Artesian Flow: G.P.M. P.S.I.					Name: Griffin Dewatering Corp		
Water Temperature: °F					Contractor		
Quality:					Address: 536 E. Maitland Street		
					Contractor		
8. WELL TEST DATA					Ontario, Ca 91761		
TEST METHOD:	Bailer	x Pump	Air Lift		Nevada contractor's license number		
	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)		issued by the State Contractor's Board C-23 0031246		
					Nevada driller's license number issued by the		
					Division of Water Resources, the on-site driller M-2264		
DOWNHOLE RECEIVED					Signed: <i>[Signature]</i>		
					By driller performing actual drilling on site or contractor		
					Date: July 9, 2007		

JUL 12 2007