STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 103342
Permit No.
Basin 212

NOTICE OF INTENT NO. 31425

1. OWNER Clark County Aviation
MAILING ADDRESS P.O. Box 11005
Las Vegas, Nv

ADDRESS AT WELL LOCATION McCarren Airport Terminal 3
5757 Wanye Newton Boulevard, Las Vegas, NV
Subdivision Name: County: CLARK

2. LOCATION NW ¼ NW ¼ Sec 35 T 21 S R 61 E
PERMIT/WAIVER No. DW-1244A Issued by Water Resources
162-35-101-018 Parcel No.
Latitude Longitude
UTM E N
NAD 27 x NAD 83/WGS 84
162-35-101-018

3. WORKED PERFORMED
Y New Well | Replace | Recondition | Deepen | x Other Dewatering Well

4. PROPOSED USE Dewater
Domestic | Irrigation | Test | Municipal/Industrial | X Monitor | Stock

5. WELL TYPE
Cable | Rotary | RVC | Air | x Other Auger Bucket

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Well # 7430				
N 486503.4 E633463.7				
Fill - gravelly clay		0	9	9
Sandy lean clay		9	14	5
Caliche - hard off white		14	16	2
Sandy lean clay		16	20	4
Fat Clay - w/gravels		20	48	28
Caliche - hard off white		48	52	4
Fat Clay - w/gravels partially cem		52	61	9
Well #7431				
N486502.8 E633263				
Fill - gravelly clay		0	9	9
Sandy lean clay		9	14	5
Caliche - hard off white		14	16	2
Sandy lean clay		16	20	4
Fat Clay - w/gravels		20	48	28
Caliche - hard off white		48	52	4
Fat Clay - w/gravels partially cem		52	61	9

Date started: 2-Jul, 20 07
Date completed: 7/2/2007, 20 07

9. WELL CONSTRUCTION
Depth Drilled 61' Feet Depth Cased 60' Feet

HOLE DIAMETER (BIT SIZE)

	From	To
24"	0	50
24" Inches	surface Feet	61' Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6.5	3.6	.280	0	30

Perforations:
Type of perforation: machine slot
Size of perforation: .032"

From 30	feet to 60	feet	
From	feet to	feet	
From	feet to	feet	
From	feet to	feet	
From	feet to	feet	

Annular Seal: Yes X No

Neat Cement	to	Pumped	Poured	
Cement Grout	to	Pumped	Poured	
Concrete Grout	to	Pumped	Poured	
≥30% Bentonite Grout	to	Pumped	Poured	
Gravel Pack: X Yes No 0 50		Pumped	X Poured	

Type: pea gravel
Bentonite Chips: Yes X No to Pumped Poured
Type:

7. Water Level
Static water level: 33 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: °F
Quality:

8. WELL TEST DATA
TEST METHOD: Bailer | Pump | Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Griffin Dewatering Corp (Contractor)
Address 536 E. Maitland Street (Contractor)
Ontario, Ca 91761
Nevada contractor's license number issued by the State Contractor's Board C-23 0031246
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-2264
Signed [signature] (By driller performing actual drilling on site or contractor)
Date July 9, 2007

(Rev. 05-06)
USE ADDITIONAL SHEETS IF NECESSARY

LAS VEGAS OFFICE