STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 103343
Permit No.
Basin 212

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER: Clark County Aviation
MAILING ADDRESS: P.O. Box 11005, Las Vegas, Nv
NOTICE OF INTENT NO. 31425
ADDRESS AT WELL LOCATION: McCarren Airport Terminal 3, 5757 Wanye Newton Boulevard, Las Vegas, NV
Subdivision Name:
County: CLARK

2. LOCATION NW ¼ NW ¼ Sec 35 T 21 S R 61 E
Latitude | UTM E | NAD 27
Longitude | N | x NAD 83/WGS 84
PERMIT/WAIVER No. DW-1244A (Issued by Water Resources)
162-35-101-018 (Parcel No.)
162-35-101-018

3. WORKED PERFORMED: [Y] New Well [ ] Replace [ ] Recondition [ ] Deepen [x] Other: Dewatering Well

4. PROPOSED USE: Dewater
[ ] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [X] Monitor [ ] Stock

5. WELL TYPE: [ ] Cable [ ] Rotary [ ] RVC [ ] Air [x] Other: Auger Bucket

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Well # 7430				
N 486503.4 E633463.7				
Fill - gravelly clay		0	9	9
Sandy lean clay		9	14	5
Caliche - hard off white		14	16	2
Sandy lean clay		16	20	4
Fat Clay - w/gravels		20	48	28
Caliche - hard off white		48	52	4
Fat Clay - w/gravels partially cem		52	61	9
Well #7431				
N486502.8 E633263				
Fill - gravelly clay		0	9	9
Sandy lean clay		9	14	5
Caliche - hard off white		14	16	2
Sandy lean clay		16	20	4
Fat Clay - w/gravels		20	48	28
Caliche - hard off white		48	52	4
Fat Clay - w/gravels partially cem		52	61	9

Date started: 2-Jul, 20 07
Date completed: 7/2/2007, 20 07

9. WELL CONSTRUCTION
Depth Drilled: 61' Feet | Depth Cased: 60' Feet

HOLE DIAMETER (BIT SIZE)
24" From 0 To 50
24" Inches surface Feet 61' Feet
Inches Feet Feet
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6.5	3.6	.280	0	30

Perforations:
Type of perforation: machine slot
Size of perforation: .032"
From 30 feet to 60 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: [ ] Yes [X] No
Neat Cement to Pumped Poured
Cement Grout to Pumped Poured
Concrete Grout to Pumped Poured
≥30% Bentonite Grout to Pumped Poured
Gravel Pack: [X] Yes [ ] No 0 50 Pumped [X] Poured
Type: pea gravel
Bentonite Chips: [ ] Yes [X] No to Pumped Poured
Type:

7. Water Level
Static water level: 33 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: °F
Quality:

8. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name (Contractor): Griffin Dewatering Corp
Address (Contractor): 536 E. Maitland Street, Ontario, Ca 91761
Nevada contractor's license number issued by the State Contractor's Board: C-23 0031246
Nevada driller's license number issued by the Division of Water Resources, the on-site driller: M-2264
Signed (By driller performing actual drilling on site or contractor): [signature]
Date: July 9, 2007

(Rev. 05-06)
USE ADDITIONAL SHEETS IF NECESSARY

RECEIVED JUL 1 2 2007
LAS VEGAS OFFICE