

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 103845-
Permit No. _____
Basin 212

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in
accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 31425

1. OWNER Clark County Aviation
MAILING ADDRESS P.O. Box 11005
Las Vegas, NV

ADDRESS AT WELL LOCATION McCarren Airport Terminal 3
5757 Wayne Newton Boulevard, Las Vegas, NV

Subdivision Name: _____ County: Clark

2. LOCATION NW ¼ NW ¼ Sec 35 T 21S N/S R 61 E
PERMIT/WAIVER No. DW-1244A Parcel No. 162-35-101-018

Latitude _____ UTM E NAD 27
Longitude _____ N NAD 83/WGS 84

3. WORKED PERFORMED
 New Well Replace Recondition
 Deepen Other Dewatering Well

4. PROPOSED USE Dewater
 Domestic Irrigation Test Monitor
 Municipal/Industrial Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other Auger Bucket

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Well # 7428				
N 486576.3 E633463.7				
Fill - gravelly clay		0	9	9
Sandy lean clay		9	14	5
Caliche - hard off white		14	16	2
Sandy lean clay		16	20	4
Fat Clay - w/gravels		20	48	28
Caliche - hard off white		48	52	4
Fat Clay - w/gravels partially cem		52	61	9
Well #7429				
N486513.9 E633463				
Fill - gravelly clay		0	9	9
Sandy lean clay		9	14	5
Caliche - hard off white		14	16	2
Sandy lean clay		16	20	4
Fat Clay - w/gravels		20	48	28
Caliche - hard off white		48	52	4
Fat Clay - w/gravels partially cem		52	61	9

9. WELL CONSTRUCTION

Depth Drilled 61' Feet Depth Cased 60' Feet

HOLE DIAMETER (BIT SIZE)

From surface To 61' BGL

24" Inches surface Feet 61' BGL Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6.5	3.6	.280	0	30

Perforations:

Type of perforation machine slot
Size of perforation .032"

From 30 feet to 60 feet

Annular Seal: Yes No

Neat Cement to Pumped Poured
 Cement Grout to Pumped Poured
 Concrete Grout to Pumped Poured
 ≥30% Bentonite Grout to Pumped Poured

Gravel Pack: Yes No to Pumped Poured
Type: pea gravel

Bentonite Chips: Yes No to Pumped Poured
Type: _____

7. Water Level

Static water level: 37 feet below land surface
Artesian Flow: _____ G.P.M. _____ P.S.I.
Water Temperature: _____ °F
Quality: _____

8. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Griffin Dewatering Corp
Contractor

Address 536 E. Maitland Street
Contractor

Ontario, Ca 91761

Nevada contractor's license number _____
issued by the State Contractor's Board C-23 0031246

Nevada driller's license number issued by the _____
Division of Water Resources, the on-site driller M-2264

Signed [Signature]
By driller performing actual drilling on site or contractor

Date July 9, 2007