

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**  
 Please complete this form in its entirety in  
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 30966

1. OWNER Flamingo Structures LLC. ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 4055 Palos Verdes St. \_\_\_\_\_  
Las Vegas, NV \_\_\_\_\_  
 2. LOCATION SW 1/4 SW 1/4 Sec. 15 T 21 N/S R 61 E Clark County \_\_\_\_\_  
 PERMIT NO. 162-15-401-013 Parcel No. \_\_\_\_\_  
 Issued by Water Resources \_\_\_\_\_ Subdivision Name GPS N. 36° 06.928' W. 115° 09.676' (WGS84)

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other Artesian

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>sand w/gravel</u>		<u>0</u>	<u>3</u>	
<u>caliche</u>		<u>3</u>	<u>4</u>	
<u>sand</u>		<u>3</u>	<u>8</u>	
<u>sand w/gravel</u>		<u>8</u>	<u>10</u>	
<u>caliche</u>		<u>10</u>	<u>14</u>	
<u>gravel</u>		<u>14</u>	<u>17</u>	
<u>clay w/sand</u>		<u>17</u>	<u>30</u>	

8. WELL CONSTRUCTION  
 Depth Drilled 30 Feet Depth Cased 30 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 9 Inches To 30 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>4"</u>	<u>PVC</u>	<u>sch 40</u>	<u>0</u>	<u>30</u>

Perforations:  
 Type perforation Factory slot  
 Size perforation .020  
 From 10 feet to 30' feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 8' to surface  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 8 feet to 30' feet

9. WATER LEVEL  
 Static water level 18' feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Elite Drilling Inc. Contractor  
 Address 4255 W. Post rd. Contractor  
Las Vegas NV 89118  
 Nevada contractor's license number issued by the State Contractor's Board 0054931  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-1869  
 Signed \_\_\_\_\_  
 By driller performing actual drilling on site or contractor  
 Date 7/24/07

Date started 7-9, 2007  
 Date completed 7-9, 2007

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	