

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 31752

1. OWNER Nevada Beverage Company ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 3940 W. Tropicana Ave Las Vegas, NV 4847 S. Valley View Blvd. LV, NV  
 2. LOCATION SE 1/4 SE 1/4 Sec. 19 T. 21 N/S R. 61 E Clark County  
 PERMIT NO. \_\_\_\_\_ Parcel No. 162-19-802-013 Lat 36.102223 Long 115.190479 N6S 84 Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG #MW-2

Material	Water Strata	From	To	Thick-ness
Gravel		0	2'	
Sandy clay		2	8'	
clay sand		8'	15'	
Sandy clay		15	17	
calich		17	20'	
clay		20	23	
Gravelly clay		23	24	
caliche		24	26	
sandy clay		26	38	
caliche		38	40	

**DCNR/DWR RECEIVED**  
AUG 02 2007

**LAS VEGAS OFFICE**

8. WELL CONSTRUCTION  
 Depth Drilled 40 Feet Depth Cased 40 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 6 Inches To 40 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2"	PVC	Sch 40	0	40

Perforations:  
 Type perforation Factory slot  
 Size perforation .020  
 From 25 feet to 40 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From 22 feet to 40 feet

Date started 7-25- 2007  
 Date completed 7-25 2007

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

9. WATER LEVEL  
 Static water level 30 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Elite Drilling Inc. Contractor  
 Address 4255 W. Post rd. Las Vegas, NV 89118 Contractor  
 Nevada contractor's license number issued by the State Contractor's Board 0054931  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-1869  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date 7-27-07