COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 103411
Permit No.
Basin 212

NOTICE OF INTENT NO. 30847

1. OWNER ETN DEVELOPMENT CORPORATION
MAILING ADDRESS 2950 INDUSTRIAL RD
LAS VEGAS, NV 89109-1100

ADDRESS AT WELL LOCATION ~~1500 ECHELON RESORT DR~~
~~LAS VEGAS, NV~~
3000 LAS VEGAS BLVD SOUTH, LV, NV

2. LOCATION SW ¼ SW ¼ Sec 09 T 21 S R 61 E CLARK County

PERMIT NO. DW1248 Issued by Water Resources
~~162-09-402-002~~ Parcel No. #
162-09-311-002 APN
ECHELON Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE DEWATER
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
6-Dewatering well				
#40,41,42,43,44, & 45				
Dirt & small gravel		0	12	
Red silty clay		13	26	
Caliche		27	38	
Tan clay		39	40	
WGS84				
N36 07. 948				
W115 10. 203				

DCNR/DWR RECEIVED AUG 24 2007 LAS VEGAS OFFICE

Date started 6/27, 20 07
Date completed 7/2, 20 07

7. WELL TEST DATE

TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION

Depth Drilled 40 Feet Depth Cased 39 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
24 Inches	0 Feet	40 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
14			+1	39

Perforations:
Type perforation Machine
Size perforation 1/4"x2.5" long 16 around
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☒ No Seal Type:
Depth of Seal ☐ Neat Cement
Placement Method: ☐ Pumped ☐ Cement Grout
☐ Poured ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 0 feet to 39 feet

9. WATER LEVEL
Static water level 23 feet below land surface
Artesian flow G.P.M P.S.I
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name ALLEN DRILLING INC. (CONTRACTOR)
Address 4015 WEST TOMPKINS AVE (CONTRACTOR)
LAS VEGAS, NV 89103
Nevada contractor's license number issued by the State Contractor's Board 18916 & 18917
Nevada driller's license number issued by the Division of Water Resources, the on-site driller MPDEW2343
Signed Timothy Ulery
By driller performing actual drilling on site or contractor
Date August 14, 2007

Forms Provided by Forms-On-A-Disk, Inc. · (214) 340-9429 · FormsOnADisk.com