COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 103460
Permit No.
Basin 212
NOTICE OF INTENT NO. 30846

1. OWNER MARE-BEAR INC
MAILING ADDRESS 2950 S INDUSTRIAL RD
LAS VEGAS, NV 89109-1100
ADDRESS AT WELL LOCATION 3000 S LAS VEGAS BLVD
LAS VEGAS, NV

2. LOCATION NW ¼ SW ¼ Sec 09 T 21 S R 61 E CLARK County
PERMIT NO. DW1247 (Issued by Water Resources) 162-09-303-007 (Parcel No.) ECHELON (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE DEWATER
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| 16-Dewatering well | | | | |
| #5,8,9,10,11,12,13,14,15, | | | | |
| 52,53,54,55,56,57 & 64. | | | | |
| dirt & small gravel | | 0 | 12 | |
| red silty caly | | 13 | 26 | |
| Caliche | | 27 | 39 | |
| Tan clay | | 39 | 40 | |
| WGS84 | | | | |
| N36 08. 022 | | | | |
| W115 10. 081 | | | | |

DCNR/DWR
RECEIVED
AUG 24 2007
LAS VEGAS OFFICE

Date started 6/22, 20 07
Date completed 6/25, 20 07

7. WELL TEST DATE

TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

8. WELL CONSTRUCTION

Depth Drilled 40 Feet Depth Cased 39 Feet

HOLE DIAMETER (BIT SIZE)

| | From | To |
|---|---|---|
| 24 Inches | 0 Feet | 40 Feet |
| Inches | Feet | Feet |
| Inches | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 14 | | | +1 | 39 |
| | | | | |

Perforations:
Type perforation Machine
Size perforation 1/4"x2.5" long 16 around
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☒ No Seal Type:
Depth of Seal ☐ Neat Cement
Placement Method: ☐ Pumped ☐ Cement Grout
☐ Poured ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 0 feet to 39 feet

9. WATER LEVEL
Static water level 23 feet below land surface
Artesian flow G.P.M P.S.I
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name ALLEN DRILLING INC. (CONTRACTOR)
Address 4015 WEST TOMPKINS AVE (CONTRACTOR)
LAS VEGAS, NV 89103
Nevada contractor's license number issued by the State Contractor's Board 18916 & 18917
Nevada driller's license number issued by the Division of Water Resources, the on-site driller MPDEW2343
Signed
By driller performing actual drilling on site or contractor
Date August 14, 2007


Forms Provided by Forms-On-A-Disk, Inc. · (214) 340-9429 · FormsOnADisk.com