

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 31214

1. OWNER **BRYAN WULFENSTEIN** ADDRESS AT WELL LOCATION **110 N CHAPPAREL**
 MAILING ADDRESS **110 N CHAPPAREL**
PAHRUMP, NV

2. LOCATION **SW 1/4 SW 1/4 Sec. 8 T 20S** N/S R **53E** E **NYE** County
 PERMIT NO. **36-107-04** **CHAPPAREL RANCHES**
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
CLAY		0	74	74
CALICHE	WB	74	76	2
CLAY		76	121	45
CALICHE	WB	121	129	8
CLAY		129	154	25
CALICHE	WB	154	159	5
CLAY		159	178	19
CALICHE	WB	178	184	6
CLAY		184	200	16

WGS84
 N 36 DEGREES 13.293
 W 116 DEGREES 02.964

8. WELL CONSTRUCTION
 Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)
 From 10 Inches To 0 Feet
0 Feet 200 Feet
 Inches Feet Feet
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	3.63	.250	0	200

Perforations:
 Type perforation **SAWCUT**
 Size perforation **1/8 X 3**

From 140 feet to 200 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 50 feet to 200-DSB feet

9. WATER LEVEL
 Static water level 67 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name **GREAT BASIN DRILLING CO. OF NEVADA, INC.**
Contractor
 Address **1220 E MANSE RD**
Contractor
PAHRUMP, NV. 89048
 Nevada contractor's license number issued by the State Contractor's Board **47333**
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller **1642**
 Signed Thomas D...
By driller performing actual drilling on-site or contractor
 Date **8/29/2007**

Date started 8/29/2007 , 19
 Date completed 8/26/2007 , 19

7. WELL TEST DATA

TEST METHOD:	Bailer		Pump		Air Lift	
	G.P.M.	Draw Down (Feet Below Static)	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	Time (Hours)