WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 103497
Permit No. 100631 48298
Basin 042

NOTICE OF INTENT NO. 44416

1. OWNER Wells City of
MAILING ADDRESS
ADDRESS AT WELL LOCATION 9th + Star

2. LOCATION SW ¼ SW ¼ Sec. 3 T 37 N/S R 62 E Elko County
PERMIT NO. 100631 48298 (Monitoring Well Abandoned) Parcel No. Subdivision Name

3. WORK PERFORMED: ☐ New Well ☐ Deepen ☐ Replace ☒ Abandon ☐ Recondition ☐ Other

4. PROPOSED USE: ☐ Domestic ☒ Municipal/Industrial ☐ Irrigation ☐ Monitor ☐ Test ☐ Stock

5. WELL TYPE: ☐ Cable ☐ Air ☐ Rotary ☐ RVC ☒ Other Unknown

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Drilled 300' 8" Column Found				
hard on ½ 25 2004 layout				
on Qt, Tailgate and to Pull Tubes				
Hatch in Roof using a Crane Truck				
July 2 - 04				
Tag Rock in Roof hatch to Total				
Depth Pump 91 Sacks of Aban Tower				
Pour 55 Super Sacks of Bar Mix				
plug into well 13,200 lbs				
Pump 36 Sacks of Neat Cement				
From 37 to Surface let Stand				

Date started 6-25, 2004
Date completed 7-2, 2004

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 340 Feet Depth Cased 340 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
24 Inches	Surface Feet	340 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
16		.375	+1	340

Perforations:
Type perforation Double Wall Slot
Size perforation 3/8 x 3/4
From Surface 125 feet to 145 feet
From Screen 145 feet to 158 feet
From Pipe 158 feet to 135 feet
From Screen 135 feet to 205 feet
From Pipe 205 feet to 215 feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal Total Depth
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☒ Neat Cement 0-7 ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 40 feet to 340 feet

9. WATER LEVEL
Static water level 35 feet below land surface
Artesian flow N/A G.P.M. P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Fred Anderson Drilling Contractor
Address 1076 Cross Valley Road Contractor
Wells NV 89835
Nevada contractor's license number issued by the State Contractor's Board 021467
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 01375
Signature By driller performing actual drilling on site or contractor
Date July 12 2004

Rev. (3-01) USE ADDITIONAL SHEETS IF NECESSARY (01-427)